



KEY NOTES

- [illegible]

EQUIPMENT NOTE

REFER TO SHEET MHE01 FOR EQUIPMENT SCHEDULES, REFER TO SHEETS MPT01 AND MPT02 FOR PIPING SCHEMATICS AND WIRING DIAGRAMS, COORDINATE WITH GENERAL CONTRACTOR. ALL ACCESS LOCATION FOR EQUIPMENT AND T-BAR CEILING REQUIREMENTS AROUND EXPOSED CEILING MOUNT UNITS.

DUCTWORK NOTE

SEE DETAILS 1 THRU 12 AND DETAIL 16 ON SHEET M501 FOR TYPICAL DUCTWORK INSTALLATION

DOOR NOTE

ALL ROOM DOORS IN INTERIOR SHALL BE UNDERCUT 1 INCH EXCEPT FOR ELECTRICAL AND DOOR BETWEEN WAITING ROOM/ OPEN OFFICE. COORDINATE FOR GENERAL CONTRACTOR TO PROVIDE UNDERCUT.