

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	691-13-102WL	RFI #:	003
Project Name:	Retrofit AHU's to VAV, B500	Date Requested:	08/18/14
Solicitation No.:	VA262-14-B-1099	Reference:	DDC Controls
Drawing:	N/A	Specification Section:	23 09 00

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

1. The specification does not call out any specific control system manufacturer. Is Schneider-Electric Andover Controls an acceptable DDC Controls system product?

OWNER RESPONSE

Response from Schwab engineering & Management:

The existing control system manufacturer is "Siemens". Contractor shall provide all controls, which shall be integrated seamlessly with the existing controls. Installation of new controls shall not put burden on the owner to keep separate inventory of a product with different manufacturer.

Responded by: Rashid Khan, Schwab engineering & Management, August 25, 2014

OWNER TRACKING No.:

AMEND No.:

VA Project Engineer/Manager:

Date: