NUMBERED NOTES (This Detail)

1. PROVIDE A PHOTOCELL ON THE LOADING DOCK BUILDING ROOF AND AIM IN A NORTHERN DIRECTION FOR CONTROL OF SITE LIGHTING.
2. ELECTRICAL CONTRACTOR SHALL COORDINATE FEED FOR SITE LIGHTING WITH LOCATION OF UNDERGROUND DUCT BANK.
3. DUCTBANK IS EXISTING. COVER ON DUCTBANK SHALL BE 24" MINIMUM. PROVIDE MAGNETIC WARNING TAPE 6" BFG ON PORTION OF DUCTBANK IN THE LIMIT OF WORK.
4. TO NEW PANELBOARD "ENTRY" LOCATED IN LOADING DOCK HOLDING ROOM, REFER TO DRAWING E200 FOR EXACT LOCATION. EXTEND (2) #10 & (1) #10 GRD IN 3/4" CONDUIT FROM PANELBOARD TO TYPE "SS" BOLLARDS.



1 ELECRICAL SITE PLAN
3/32" = 1'-0"

NORTH

FULLY SPRINKLERED BID DOCUMENTS

Revisions:	Date

CONSULTANTS:

HOPE FURRER Associates, Inc.

REGISTERED PROFESSIONAL ENGINEER JASON J. TECHECK 084-EC-E0018

ARCHITECTS/ENGINEERS:

A|E works
6587 HAMILTON AVENUE
PITTSBURGH, PENNSYLVANIA 15206
PH: 412.287.7333 FAX: 412.287.7334
www.ae-works.com

Drawing Title	ELECTRICAL SITE PLAN
Approved: Project Director	
Project Title	BUILDING 9 - SECOND FLOOR RENOVATION
Location:	1400 Blackhorse Hill Road Coatesville, PA 19320
Date	05 / 12 / 14
Checked	JJD
Drawn	JMZ
Project Number	542-13-105
Building Number	9
Drawing Number	E002
Dwg. 98 of 125	

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231