

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				BPA NO.		1. CONTRACT ID CODE		PAGE 1		OF PAGES 3									
2. AMENDMENT/MODIFICATION NO. A00001				3. EFFECTIVE DATE		4. REQUISITION/PURCHASE REQ. NO.				5. PROJECT NO.(If applicable) 660-14-07S									
6. ISSUED BY CODE Department of Veterans Affairs Network Contracting Office NCO 19 4100 E. Mississippi Avenue, Suite 900 Glendale CO 80246				00259		7. ADMINISTERED BY (If other than Item 6) CODE Department of Veterans Affairs Network Contracting Office NCO 19 4100 E. Mississippi Avenue, Suite 900 Glendale CO 80246				00259									
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) To all Offerors/Bidders						(X)		9A. AMENDMENT OF SOLICITATION NO. VA259-14-R-0637											
								9B. DATED (SEE ITEM 11) 09-04-2014											
								10A. MODIFICATION OF CONTRACT/ORDER NO.											
								10B. DATED (SEE ITEM 13)											
CODE						FACILITY CODE													
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS																			
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.																			
12. ACCOUNTING AND APPROPRIATION DATA (If required)																			
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.																			
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:5%;">(X)</td> <td style="width:95%;">A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.</td> </tr> <tr> <td></td> <td>B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).</td> </tr> <tr> <td></td> <td>C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:</td> </tr> <tr> <td></td> <td>D. OTHER (Specify type of modification and authority)</td> </tr> </table>												(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.		B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).		C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:		D. OTHER (Specify type of modification and authority)
(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.																		
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).																		
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:																		
	D. OTHER (Specify type of modification and authority)																		
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return ¹ _____ copies to the issuing office.																			
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)																			
a) A site visit was held on 8/26/2014 and the list of attendees is attached. b) Questions and answers received prior to the date required for submission are attached. c) The date set for the receipt of offers has been changed to 9/11/2014 at 3:00 pm (MST)																			
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.																			
15A. NAME AND TITLE OF SIGNER (Type or print)						16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)													
						Andrew Stigen Contracting Officer													
15B. CONTRACTOR/OFFEROR				15C. DATE SIGNED		16B. UNITED STATES OF AMERICA				16C. DATE SIGNED									
(Signature of person authorized to sign)						BY (Signature of Contracting Officer)													
<div style="display: flex; justify-content: space-between;"> NSN 7540-01-152-8070 PREVIOUS EDITION NOT USABLE STANDARD FORM 30 (REV. 10-83) Prescribed by GSA - FAR (48 CFR) 53.243 </div>																			

GEORGE E. WAHLEN
DEPARTMENT OF VETERANS AFFAIRS MEDICAL CENTER
VA Salt Lake City Health Care System
500 Foothill Drive
Salt Lake City, UT 84148

**Nurse Station Construction Project
660-14-07S**

Sign In Sheet 8/26/2014

Name:

Company name:

Phone:

Email:

[illegible]

Question

1. Who is installing the furnishings notes in the SOW and contract drawings?

- The Furniture will be installed by Henriksen/Butler Design Group—Installation Division.

2. Are the electrical connections single point connections?

- The “Electrical Furniture Whips” are an 8 wire system for 4 circuits—this does not mean that there are 4 circuits already pulled to each point or that 4 circuits will be required. There is a certain amount of discovery that will take place during demolition. (These will be used for the “front” sections of each Nurse Station.)

- The Nurse Stations are on Emergency Power and will continue to be on emergency power.

- The “back” section of each Nurse Station currently has exterior Wall molding with the power running through it, as this is mounted over the existing support brackets it will need to be removed and the **power and data** that is existing will need to be dropped into the walls.

3. Is the circuitry connections to be placed on existing circuits or are new circuits required?

- The current connects will stay on the existing circuits. The additional 5 electrical drops per station (15 total new drops) as requested in the SOW will need to be on new circuits. Coordination with VAMC maintenance staff will be required.

4. Is any additional power required?

- As per the SOW 5 additional power and Data drops per Nurses Station (15 total new drops) are required.

Please Note: The DATA drops are as critical as the electrical.