

NON-RATED

G INTERIOR PARTITION - 6" STUD w GWB BOTH SIDES		D INTERIOR FURRING - 4" STUD w GWB ONE SIDE		A (N) 4" STUD PART HT. w GWB BOTH SIDES	
PLAN VIEW SYMBOL		PLAN VIEW SYMBOL		PLAN VIEW SYMBOL	
(N) 6" MTL STUD W/ GWB ON BOTH SIDE	OVERALL WIDTH: 0' - 0"	(N) 4" MTL STUD W/ GWB ON ONE SIDE	OVERALL WIDTH: 0' - 0"	(N) 4" MTL STUD W/ GWB ON BOTH SIDES	OVERALL WIDTH: 0' - 0"
ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF 6" 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS	6" METAL STUD 5/8" GYP. BD.	ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO ONE SIDE OF 4" 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS	4" METAL STUD 5/8" GYP. BD.	ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS AND 12" O.C. FACE LAYER 5/8" TYPE X GYPSUM WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO ONE SIDE WITH 1 5/8" TYPE S DRYWALL SCREWS 12" O.C. JOINTS STAGGERED 24" O.C. EACH LAYER AND SIDE.	4" METAL STUD 5/8" GYP. BD.
H INTERIOR 4" STUD PART HT w GWB BOTH SIDES w LEAD LINING ONE SIDE		E INTERIOR FURRING - 4" STUD w GWB ONE SIDE w LEAD LINING ONE SIDE		B (E) 4" STUD PART HT w (N) GWB & LEAD LINING ONE SIDE	
PLAN VIEW SYMBOL		PLAN VIEW SYMBOL		PLAN VIEW SYMBOL	
4" MTL STUD W/ LEAD LINING AND GWB ON BOTH SIDES	OVERALL WIDTH: 0' - 0"	(N) 4" MTL STUD W/ LEAD LINING AND GWB ON ONE SIDE	OVERALL WIDTH: 0' - 0"	(N) 4" MTL STUD W/ LEAD LINING AND GWB ON ONE SIDE	OVERALL WIDTH: 0' - 0"
ONE LAYER LEAD LINING TO 7'-0" A.F.F. WITH 4" LEAD BATTEN AT GWB JOINTS AND TOP OF LINING - SEE SHT AS7-23	4" METAL STUD	ONE LAYER LEAD LINING TO 7'-0" A.F.F. WITH 4" LEAD BATTEN AT GWB JOINTS AND TOP OF LINING - SEE SHT AS7-23	4" METAL STUD	ONE LAYER LEAD LINING TO 7'-0" A.F.F. WITH 4" LEAD BATTEN AT GWB JOINTS AND TOP OF LINING - SEE SHT AS7-23	(E) 4" METAL STUD
ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF 4" 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS AND 12" O.C. FACE LAYER 5/8" TYPE X GYPSUM WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO ONE SIDE WITH 1 5/8" TYPE S DRYWALL SCREWS 12" O.C. JOINTS STAGGERED 24" O.C. EACH LAYER AND SIDE.	(N) 4.0 LBS S/QFT LEAD LINING - SEE SPECIFICATIONS (N) 5/8" GYP. BD.	ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO ONE SIDE OF 4" 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS	4.0 LBS S/QFT LEAD LINING - SEE SPECIFICATIONS 5/8" GYP. BD.	ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF 4" 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS AND 12" O.C. FACE LAYER 5/8" TYPE X GYPSUM WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO ONE SIDE WITH 1 5/8" TYPE S DRYWALL SCREWS 12" O.C. JOINTS STAGGERED 24" O.C. EACH LAYER AND SIDE.	(N) 4.0 LBS S/QFT LEAD LINING - SEE SPECIFICATIONS (N) 5/8" GYP. BD.
J INTERIOR PARTITION - 6" STUD w GWB AND TILE WALL COVERING, BOTH SIDES		F INTERIOR PARTITION - 6" STUD w GWB BOTH SIDES w TILE WALL COVERING		C INTERIOR PARTITION - 4" STUD w GWB BOTH SIDES w TILE WALL COVERING	
PLAN VIEW SYMBOL		PLAN VIEW SYMBOL		PLAN VIEW SYMBOL	
(N) 6" MTL STUD W/ GWB AND C.T. ON BOTH SIDES	OVERALL WIDTH: 0' - 0"	(N) 6" MTL STUD W/ GWB ON ONE SIDE W/ C.T. FINISH	OVERALL WIDTH: 0' - 0"	(N) 4" MTL STUD W/ GWB ON BOTH SIDES W/ C.T. FINISH	OVERALL WIDTH: 0' - 0"
ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF (N) 6" 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS CERAMIC TILE THIN-SET WALL COVERING TO 6'-6" A.F.F. W TRIM TILE AT EXPOSED EDGES U.O.N.	6" METAL STUD 5/8" GYP. BD. C.T. WALL COVERING - SEE INTERIOR ELEV.	ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF (N) 6" 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS CERAMIC TILE THIN-SET WALL COVERING TO 6'-6" A.F.F. W TRIM TILE AT EXPOSED EDGES U.O.N.	6" METAL STUD 5/8" GYP. BD. C.T. WALL COVERING - SEE INTERIOR ELEV.	ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF (N) 4" 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS AND 12" O.C. FACE LAYER 5/8" TYPE X GYPSUM WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO ONE SIDE WITH 1 5/8" TYPE S DRYWALL SCREWS 12" O.C. JOINTS STAGGERED 24" O.C. EACH SIDE. CERAMIC TILE THIN-SET WALL COVERING TO 4'-0" A.F.F. W TRIM TILE AT EXPOSED EDGES.	4" METAL STUD 5/8" GYP. BD. C.T. WALL COVERING - SEE INTERIOR ELEV.

2 HOUR

1A

**(N) 6" STUD FULL HT
W GWB BOTH SIDES**

PLAN VIEW SYMBOL

2 HR PARTITIONED

OVERALL
WIDTH:

0' - 7 1/4"

ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF 6" 20 GA STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 12" O.C. AT VERTICAL JOINTS AND 12" O.C. FACE LAYER 5/8" TYPE X GYPSUM WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO ONE SIDE WITH 1 5/8" TYPE S DRYWALL SCREWS 12" O.C.

JOINTS STAGGERED 24" O.C. EACH SIDE.

3 1/2" GLASS FIBER FRICTION FIT IN STUD SPACE.

1B

**(N) 6" STUD FULL HT
W GWB BOTH SIDES
W LEAD LINING ONE SIDE**

PLAN VIEW SYMBOL

2 HR RATED PARTITION

OVERALL
WIDTH:

0' - 7 1/4"

ONE LAYER LEAD LINING TO 7'-0" A.F.F. WITH 4" LEAD BATTEN AT GWB JOINTS AND TOP OF LINING - SEE SHT AS7-23

ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF 6" 20 GA. STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS AND 12" O.C. FACE LAYER 5/8" TYPE X GYPSUM WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO ONE SIDE WITH 1 5/8" TYPE S DRYWALL SCREWS 12" O.C.

JOINTS STAGGERED 24" O.C. EACH SIDE.

1C

**(E) & (N) 4" STUD FULL HT
W GWB BOTH SIDES
W LEAD LINING ONE SIDE**

PLAN VIEW SYMBOL

2-HR RATED PARTITION
FULL HT TO SLAB

OVERALL
WIDTH:

0' - 5 5/16"

ONE LAYER LEAD LINING TO 7'-0" A.F.F. WITH 4" LEAD BATTEN AT GWB JOINTS AND TOP OF LINING - SEE SHT AS7-23

ONE LAYER 5/8" TYPE X WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF (E) & STAGGERED (N) 4" 20 GA STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8" O.C. AT VERTICAL JOINTS AND 12" O.C. FACE LAYER 5/8" TYPE X GYPSUM WALLBOARD APPLIED PARALLEL OR AT RIGHT ANGLES TO ONE SIDE WITH 1 5/8" TYPE S DRYWALL SCREWS 12" O.C.

JOINTS STAGGERED 24" O.C. EACH SIDE.

3 1/2" GLASS FIBER FRICTION FIT IN STUD SPACE.

INTERIOR WALLS

Project Number
640-13-134

Building Number
100

Drawing Number
AS6-15

Dwg. of

Department of
Veterans Affairs

Location VAPAHCS - PALO ALTO CAMPUS 3801 MIRANDA AVE, PALO ALTO, CA 94304		
Date 08.22.2014	Checked	Drawn Author

Drawing Title

Approved: Project Director



Hilliard
ARCHITECTS

4

Date

VA FORM 08-6231