

REQUEST FOR INFORMATION (RFI)
VA-251-14-B-0330

PROJECT NUMBER:	655-10-106	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.
PROJECT TITLE:	Paving Parking Lots & Exterior Improvements	
PROJECT LOCATION:	Department of Veterans Affairs VA Medical Center 1500 Weiss Street Saginaw, MI 48602	

SUBMITTED BY:	DBC	City/State:	
PHONE NO.:			

TO:
Aleda E. Lutz VAMC
Department of Veterans Affairs
Attn: Contracting Office, 90CSC
1500 Weiss Street
Saginaw, MI 48602

RFI NO.:	DATE: 8/25/14	SPEC/DWG. REFERENCE:
REPLY NEEDED BY:		

INFORMATION NEEDED:

Per 05 12 00-1.3, does steel for this project have to be fabricated in an AISC certified plant or can other quality assurance certifications be acceptable? There are only a handful of plants in Michigan which are AISC certified.

REPLY:

AISC Certification for the fabrication is not required.

REPLY FROM:
ATTACHMENTS:

Tom Belongia

Digitally Signed at 3:28 pm, on September 04 2014