

REQUEST FOR INFORMATION (RFI)
VA-251-14-B-0330

PROJECT NUMBER:	655-10-106	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.
PROJECT TITLE:	Paving Parking Lots & Exterior Improvements	
PROJECT LOCATION:	Department of Veterans Affairs VA Medical Center 1500 Weiss Street Saginaw, MI 48602	

SUBMITTED BY:	DBC	City/State:	
PHONE NO.:			

TO:

Aleda E. Lutz VAMC
Department of Veterans Affairs
Attn: Contracting Office, 90CSC
1500 Weiss Street
Saginaw, MI 48602

RFI NO.:	DATE: 8/26/14	SPEC/DWG. REFERENCE:
REPLY NEEDED BY:		

INFORMATION NEEDED:

1) PLEASE PROVIDE SPEC FOR FLAG POLE. I COULD NOT LOCATE IN THE DOCUMENTS.

2) ARE BENCHES SHOWN ON CANOPY PLANS IN OUR SCOPE IF SO PLEASE PROVIDE SPEC. I COULD NOT LOCATE IN THE DOCUMENTS.

REPLY:

1. There is not a flagpole specification. A flagpole manufacturer was indicated on Detail 5/SS106 (80' Valmont Structured Flagpole) with an "OR EQUAL" indicated.
2. Yes, All Benches shown are part of the scope. Basis of Design: MAGLIN BENCH, MLB400-RC-D3 or Approved Equivalent, with skate deterrent.

REPLY FROM: Tom Belongia	DATE: 9-4-2014
ATTACHMENTS:	COPY TO: