

REQUEST FOR INFORMATION (RFI)
VA-251-14-B-0330

PROJECT NUMBER:	655-10-106	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Paving Parking Lots & Exterior Improvements		
PROJECT LOCATION:	Department of Veterans Affairs VA Medical Center 1500 Weiss Street Saginaw, MI 48602		
SUBMITTED BY:	STE Contracting	City/State:	Mt. Clemens MI
PHONE NO.:	5864681135		

TO:

Aleda E. Lutz VAMC
Department of Veterans Affairs
Attn: Contracting Office, 90CSC
1500 Weiss Street
Saginaw, MI 48602

RFI NO.:5	DATE:9-2-14	SPEC/DWG. REFERENCE: CS106
REPLY NEEDED BY: yes		

INFORMATION NEEDED:

What is the size of the 3 new storm sewer that run south off CB #300?

REPLY:

2" diameter



Digitally Signed at 5:08 pm, on September 05 2014

REPLY FROM: Jay C. Wheeler, PE	DATE: 09/05/14
ATTACHMENTS: None	COPY TO: T. Belongia, VA COR