



- ① REMOVE EXISTING WOOD ACCESS DOOR AND INSTALL NEW ACCESS DOOR.
- ② VETERAN EXPLAINED TO CM THAT THE EXISTING ELECTRICAL PANEL TRIPS BREAKERS OFTEN. THE GENERAL CONTRACTOR SHALL HAVE A CERTIFIED ELECTRICIAN INSPECT EXISTING 200 AMP PANEL AND PROVIDE A RECOMMENDATION TO CORRECT THE ISSUE.
- ③ THE PRESENCE OF MOISTURE ON THE BOTTOM 2 LAYERS OF 8" CMU WAS VISIBLE IN BASEMENT. EXISTING CMU FOUNDATION MAY REQUIRE WATERPROOFING AND/OR FRENCH DRAINS. CONTRACTOR TO INSPECT AND PROVIDE A RECOMMENDATION TO CORRECT THE ISSUE.

VA FORM 08-6231



