



TRANSFORMER MOUNTING NOTES:

- ① SPILL CONTAINMENT CONCRETE PAD. EXACT PAD SIZE TO BE DETERMINED DEPENDING ON THE ACTUAL SIZE OF THE TRANSFORMER.
- ② 3/4" x 6" HEADER ANCHOR BOLTS AND DOUBLE LOCK NUTS. ONE AT EACH CORNER. MINIMUM 5" EMBEDMENT.
- ③ PRIMARY CONDUITS WINDOW.
- ④ SECORNDARY CONDUITS WINDOW.
- ⑤ PRIMARY CONDUIT.
- ⑥ SECONDARY CONDUIT.
- ⑦ GROUT IN AROUND CONDUITS.
- ⑧ 3/4"Ø x 8' COPPER GROUND ROD.
- ⑨ #2 BARE SOLID COPPER GROUND WIRE.