



1. CONTRACTOR SHALL HIRE A CERTIFIED MEDICAL GAS TESTING AGENCY TO VERIFY MEDICAL GAS INSTALLATION AND COMPLETE ALL TEST IN ACCORDANCE WITH THE SPECIFICATIONS AND NFPA 99.

2. TESTING AGENCY SHALL COMPLETE VERIFICATION AND TESTING FOR EACH INDIVIDUAL PHASE, THUS AT THE END OF EACH PHASE THE CONTRACTOR WILL TURN OVER A COMPLETE MEDICAL GAS SYSTEM THAT HAS BEEN INSPECTED AND TESTED.

3. WORK SHOWN OUTSIDE OF PHASE BOUNDARY WILL BE INSTALLED AFTER HOURS ABOVE EXISTING CEILING. THIS CONTRACTOR SHALL REMOVE AND REPLACE CEILING AS REQUIRED TO COMPLETE THIS WORK. THIS CONTRACTOR SHALL PROTECT OCCUPIED AREA AND CLEAN UP AFTER THE END OF EACH SHIFT. THIS WORK SHALL BE COORDINATED WITH AND SCHEDULED THROUGH THE COTR.

- ① LOCATION FOR NEW MEDICAL GAS AREA ALARM PANEL.
- ② NOT USED.
- ③ EXISTING MEDICAL GAS SENSORS.
- ④ NEW 1" MEDICAL OXYGEN, 3/4" MEDICAL AIR AND 1-1/4" MEDICAL VACUUM TO SUB-BASEMENT. CONNECT TO EXISTING 1" MEDICAL OXYGEN, 1-1/4" MEDICAL VACUUM AND 3/4" MEDICAL AIR MAINS.
- ⑤ 3/4" MEDICAL OXYGEN, 1/2" MEDICAL AIR AND 1-1/4" MEDICAL VACUUM VALVED AND CAPPED FOR FUTURE EXTENSION.
- ⑥ 1/2" MEDICAL OXYGEN, 1/2" MEDICAL AIR AND 3/4" MEDICAL VACUUM VALVED AND CAPPED FOR FUTURE EXTENSION.
- ⑦ PROVIDE NEW MEDICAL GAS PRESSURE SENSORS WITH WITH DISS NIPPLE CHECK, WIRE BACK TO AREA ALARM PANEL.

①