



CABLE LINKS CONSTRUCTION

5940 E. Shields Ave. Ste. 101, Fresno CA 93727
(559) 277-8555, Fax (559) 274-1555, www.cablelinks.us

R.F.I.

(REQUEST FOR INFORMATION)

Project #:	VA261-14-R-1357	RFI #:	1
Project Name:	Install Nurse Call System	Date Requested:	9/12//2014
Owner	Department of Veteran Affairs	Reference:	Nurse Call
Drawing:	NC1	Specification Section:	

DESCRIPTION OF PROBLEM OR INFORMATION REQUESTED

Can you please clarify the following please.....

1. Please provide a Symbol/Equipment list to define each symbol on the drawings and a description or specification for each device
2. Please confirm the statement made at the walk through, the system would be standalone and it did not need to connect to the existing nurse call system on the 5th floor.
3. Is the new nurse call system open to substitution or will you provide the brand model and part numbers for all smarts and parts that you're specifying?

OWNER RESPONSE

1. The drawing was to give an overview of the room. You would be only responsible to install a single gang box on the wall above the patient bed and run a conduit to the dome light above the door to the room.
2. The conduit run just have to be ran to the existing nurse call unit and left with the ability to connect to the dome light box. This will not require a new unit to be purchased.
3. You are only responsible for a conduit run, not a nurse call system. The parts used for the conduit must comply with industry standards.

Cliff Harris 559-225-6100 x5214

OWNER TRACKING No.:

AMEND No.:

Project Engineer/Manager:

Date: