


- A. REFER TO SHEET F-001 FOR LEGEND, ABBREVIATIONS, AND GENERAL NOTES.
- B. RENOVATION NOTATIONS:
 - (R) LOCATION OF RELOCATED DEVICE OR EQUIPMENT
 - (RR) REMOVE AND RELOCATE EXISTING DEVICE OR EQUIPMENT
 - (X) EXISTING DEVICE OR EQUIPMENT TO REMAIN
 - (XR) EXISTING FIRE ALARM DEVICE OR EQUIPMENT THAT HAS BEEN REMOVED AND REPLACED WITH NEW, RE-USE EXISTING CONDUIT WHENEVER POSSIBLE.
- C. ALL AREAS SHALL BE CONSIDERED TO HAVE A LAY-IN CEILING UNLESS NOTED OTHERWISE.
- D. THE CONTRACTOR SHALL BE RESPONSIBLE FOR CUTTING AND PATCHING WALLS AND CEILINGS. MATCH EXISTING FINISHES.
- E. ALL FIRE ALARM WIRING SHALL BE IN CONDUIT.

1. ALL SPRINKLER LOW PRESSURE, TAMPER, AND FLOW SWITCHES ARE EXISTING TO REMAIN. REMOVE EXISTING FIRE ALARM INTERFACE MODULES AND FURNISH AND INSTALL NEW MODULES FOR MONITORING BY NEW SYSTEM.
2. FURNISH AND INSTALL NEW CONTROL MODULES FOR EXISTING SECURITY WINDOW RELEASE.
3. EXISTING DOOR SHUTTER TO REMAIN, ADD MONITOR MODULE TO EXISTING DOOR SHUTTER, CONNECT F/A CIRCUITING TO NEW FACP.
4. EXISTING FIRE SHUTTER TO REMAIN, ADD MONITOR MODULE TO EXISTING FIRE SHUTTER, CONNECT F/A CIRCUITING TO NEW FACP.



KEY PLAN
NTS

**FULLY SPRINKLERED
BID DOCUMENTS**

		<div>ARCHITECT/ENGINEERS:</div> <div><div>PARADIGM</div><div>ENGINEERS AND CONSTRUCTORS</div></div> <div>200 Envoy Circle #201, Louisville KY 40239 – PH: 502.339.8511 – www.paradigmusa.com</div>	<div>ALL WORK TO BE IN ACCORDANCE WITH N.F.P.A., NATIONAL, STATE AND CITY CODES & O.S.H.A.</div> <div>Approved: Logistics Manager. Date</div> <div>Approved: Infection Control Mgr. Date</div> <div>Approved: Chief Security Date</div>	<div>Approved: A.F.G.E. Date</div> <div>Approved: Interior Designer Date</div> <div>Approved: Info. Sys. Date</div> <div>Approved: Women's Health Rep Date</div>	<div>Approved: Fire Chief Date</div> <div>Approved: Safety Officer Date</div> <div>Approved: Industrial Hygienist Date</div> <div>Approved: Space Owner Date</div>	<div>Approved: Patient Safety Date</div> <div>Approved: M&R Foreman Date</div> <div>Approved: Industrial Hygienist Date</div> <div>Approved: Associate Director Date</div>	<div>Drawing Title</div> <div>FIRE ALARM - FIRST FLOOR PLAN NORTH</div> <div>Approved: Eng. Project Supervisor Date</div> <div>Approved: Medical Center Director Date</div>	<div>Project Title</div> <div>UPGRADE FIRE ALARM SYSTEM BUILDING 76</div> <div>Building No. 76</div> <div>Location</div> <div>BATH, NEW YORK</div>	<div>Date</div> <div>07-21-2014</div> <div>Project No.</div> <div>528A6-14-601</div> <div>DRAWING NO.</div> <div>VAMC-528A6-0012</div> <div>FA104</div> <div>Dwg. 17 of 33</div>	<div><div><div></div><div></div></div></div>	
	AMENDMENT #2	08/26/2014									
	AMENDMENT #1	08/14/2014									
	Revisions	Date									