

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.

1. CONTRACT ID CODE

PAGE

OF PAGES

1

2

2. AMENDMENT/MODIFICATION NO.

A00001

3. EFFECTIVE DATE

10-10-2014

4. REQUISITION/PURCHASE REQ. NO.

675-15-1-3274-0001

5. PROJECT NO. (If applicable)

675-15-600

6. ISSUED BY

CODE

Department of Veterans Affairs
Orlando VA Medical Center
5201 Raymond Street

Orlando FL 32803

7. ADMINISTERED BY (If other than Item 6)

CODE 00675

Department of Veterans Affairs
Network Contracting Activity 8 (NCO 8)
Orlando VA Medical Center
5201 Raymond Street
Orlando FL 32803

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)

To all Offerors/Bidders

(X) 9A. AMENDMENT OF SOLICITATION NO.

VA248-14-R-2168

9B. DATED (SEE ITEM 11)

X 10-08-2014

10A. MODIFICATION OF CONTRACT/ORDER NO.

10B. DATED (SEE ITEM 13)

CODE

FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

X The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, X is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(X) A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

This amendment serves to address all Requests For Information submitted 10-08-2014 Through 10-10-2014.

See continuation page

***** Last Item *****

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

Cory Pfenning
Contract Specialist

V810L1-2818

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

(Signature of person authorized to sign)

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

BY

(Signature of Contracting Officer)

10/10/2014

DEPARTMENT OF VETERANS AFFAIRS

Orlando VA Medical Center

5201 Raymond Street



REQUEST FOR INFORMATION # 1

Project: 675-15-600

Solicitation No.: VA248-14-R-2168

Date: 10-08-14

To: Resident Engineer

cc: N/A

From: Undisclosed Vendor

Subject: 100 gallon day tanks

Please provide the following information or clarification:

Regarding the three 100 gallon day tanks, if it is the gauges and floats that are not functioning properly, why not just replace them and add electronic monitoring and filters?

Response required by 10-09-14

Date: 10-09-14

To: Contracting Officer

From: Resident Engineer

Subject: Response to RFI No 1

The tanks are original and past their service life. Retrofitting old tanks to accept the technology would not be worth the cost and the tanks would still be 30 years old. They are not built to have additional controls and monitoring that the new tanks will have; and they will not have glass gauge to see actual fluid level. The tanks must be replaced.
