



420 Rail Street  
Negaunee, MI 49866  
906-475-6616  
WWW.NDW.US

## ADDENDUM

---

Number: 4	Project Number: 1211
Project: IMVA-Expand Imaging 585-12-112	Date: November 3, 2014

---

The contractor shall acknowledge receipt of all addenda by listing the number where indicated on the bid form.

Drawings, specifications, and / or proposals are herein amended, expanded, and / or modified, and become a part of the Contract Documents with the same effect as if incorporated in the original documents. Any contrary provisions contained, or referred to, in Drawings and / or Specifications, shall remain applicable unless overridden by this Addendum. Revised provisions herein shall include all labor, materials, methods, modifications, etc. required for the completion of the Work.

---

### Specification Modifications:

08 71 13- Automatic Door Operators- Not Reissued  
Section 1.3 Quality Assurance, remove paragraph A and renumber paragraph B to A.

### Drawing Modifications:

1. Sheet E002- Electrical Notes, Symbols, Schedules and Abbreviations- Added additional information to the Electrical Symbols Communication Legend.
2. Sheet EY504- Electrical Riser Diagram- Modified panel text in Detail 2 from 225A to 100A.
3. Sheet EY506- Electrical Panelboards- Added additional information to the following schedules: X-RAY, CR2C, LS2C, PACS, CR2B, E2A as indicated.

Attachments: E002, EY504, EY506.

End of Addendum

---