

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT	BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF PAGES
---	---------	---------------------	-----------	----------

2. AMENDMENT/MODIFICATION NO. A00001	3. EFFECTIVE DATE 11-14-2014	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO.(If applicable) None
---	---------------------------------	----------------------------------	---------------------------------------

6. ISSUED BY Department of Veterans Affairs Network Contracting Office 6 100 Emancipation Drive Hampton VA 23667	CODE	7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Network Contracting Office 6 100 Emancipation Drive Hampton VA 23667	CODE
--	------	---	------

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) To all Offerors/Bidders	(X)	9A. AMENDMENT OF SOLICITATION NO. VA246-15-Q-0080
	X	9B. DATED (SEE ITEM 11) 11-14-2014
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. **FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

1. The purpose of this amendment is to:
 - a. Answer questions posed by industry about the requirement
 - b. Establish a cut-off date and time for receipt of questions in regards to this requirement.

As a result of this Amendment:

- a. Questions received and the Government's Response are attached to this SF30 (see continuation page).
- b. The suspense for submission of questions is now set for 17 Nov 2014 by 4:00 pm EST. Questions submitted beyond this established date and time may not be addressed.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED
16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED

CONTINUATION PAGE

Questions from industry and Government Response

1. Are the sizes listed the exact size needed?
 - a. Currently, Attachment I: Master Filter List, contains all the exact sizes required. As equipment is retired and/or replaced and new equipment is put into service, the Master List will be updated on an as needed basis.
2. Will they be rated for standard capacity or high capacity?
 - a. HEPA Filters requirements are for standard capacity.
3. Are they going to be a c-style frame or other?
 - a. HEPA Filters are not C-style.
4. Is there a gasket on these filters and what is the location?
 - a. There are no gaskets on the HEPA filters contained within Attachment I.