Qty	Description	Service Frequency	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov
1	Central System Performance Review	Monthly	1	1	1	1	1	1	1	1	1	1	1	1
2	Rebuild Carbon Head	Annually		2										
2	Carbon Filter Rebed, 8 cuft	Annually		2										
6	DI Tanks	Semi-Annually		3						3				
16	Disinfect Membranes	Semi-Monthly	2	2	2	2	1	1	1	1	1	1	1	1
16	Disinfect Loop	Semi-Monthly	2	2	2	2	1	1	1	1	1	1	1	1
16	Perform & Replace Central RO Prefilter	Semi-Monthly	2	2	2	2	1	1	1	1	1	1	1	1
16	Central RO Prefilter, 10", 5M BB	Semi-Monthly	2	2	2	2	1	1	1	1	1	1	1	1
2	Perform & Replace Pyrogen	Semi-Annually		1						1				
2	Pyrogen Filter, .05M, 20"	Semi-Annually		1						1				
2	Central Vent Filter	Semi-Annually		1						1				
2	Bacteria Filter .2M, 10"	Semi-Annually		1						1				
1	Rebed Water softener	Annually		1										
1	Rebuild the softener head	Annually		1										
1	Brine tank to be emptied and cleaned	Annually		1										
1	UV lamps	Annually		1										
1	UV lamp Quartz sleeve change	Annually		1										