



1010 Kings Highway South
Building Two – 2nd Floor
Cherry Hill, NJ 08034

Phone: 856-429-4000
Fax: 856-429-5002
E-mail: office@miller-remick.com

Request for Information

Contractor RFI No.: 1.0

Request Date: 11/25/14

Contractor/Supplier: TBD

M-R RFI Log No.: 01

Response Date: 00/00/14

VA Project No.: 528-13-C-0179

M-R Project No.: 3-0499-0046

Project Name: Renovate 6B Ward Syracuse VAMC

RFI: (Attachments ☐ Yes ☒ No)

Sandra,

Please see below RFI

- In spec section 102600, they talk about Patient Bed Locator, but these are not shown on the drawings as to where they go.

RFI Response:

Bed locators are shown on typical patient headwall elevation detail 1F on Dwg. AS-204.

Anthony Lapczynski, I.C.C. Certified
QPK Design, Inc.

11/25/14

DOCUMENT1

Reviewed By: