



1010 Kings Highway South  
Building Two – 2nd Floor  
Cherry Hill, NJ 08034

Phone: 856-429-4000  
Fax: 856-429-5002  
E-mail: office@miller-remick.com

## Request for Information

Contractor RFI No.: 2.0

Request Date: 11/25/14

Contractor/Supplier: TBD

M-R RFI Log No.: 01

Response Date: 00/00/14

VA Project No.: 528-13-C-0179

M-R Project No.: 3-0499-0046

Project Name: Renovate 6B Ward Syracuse VAMC

RFI: (Attachments ☐ Yes ☒ No)

Sandra,

Please see below RFI

. The new Aluminum windows are not called out on the plans as to what windows are what types, the demo shows the removal of all the windows, but nothing on the plans as to what windows are what.

### RFI Response:

All single windows shown on the plan as a single window shall be a type "A" windows as shown on drawing AS-400 detail 1A Window schedule

All double windows shown on the plans shall be a type "B" windows as shown on drawing as-400 detail 1A

Anthony Lapczynski, I.C.C. Certified  
QPK Design, Inc.

11/25/14

DOCUMENT1

Reviewed By: