

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF PAGES 2
2. AMENDMENT/MODIFICATION NO. A00001		3. EFFECTIVE DATE 12/10/2014		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) 0
6. ISSUED BY CODE Department of Veterans Affairs VAMC Manchester 718 Smyth Road Manchester NH 03104		7. ADMINISTERED BY (If other than Item 6) CODE Department of Veterans Affairs VAMC Manchester 718 Smyth Road Manchester NH 03104				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) To all Offerors/Bidders				(X)	9A. AMENDMENT OF SOLICITATION NO. VA241-15-Q-0018	
				X	9B. DATED (SEE ITEM 11) 11-13-2104	
					10A. MODIFICATION OF CONTRACT/ORDER NO.	
					10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. Tuesday, January 20, 2015 @ 12 Noon.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
	D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this Amendment is to change the solicitation response date to Tuesday, January 20, 2015 @ 12 noon. Also there are documents attached: Site map w/plans and questions and answers from site visit.						
All other terms and conditions will remain unchanged.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Carol Domingue Contracting Officer			
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY: (Signature of Contracting Officer)		16C. DATE SIGNED 12/10/2014	
NSN 7540-01-152-8070 PREVIOUS EDITION NOT USABLE						
STANDARD FORM 30 (REV. 10-83) Prescribed by GSA - FAR (48 CFR) 53.243						

Solicitation#: VA241-15-Q-0018

Amendment# 00001, Questions from site visit

- Q1. Are the Davis Bacon Wages going to be used for this requirement:
- a. **There is no construction involved in this contract so the wages to be paid out will fall under the Service Contract Act. WD 05-2255 (Rev.-16) was first posted on www.wdol.gov on 08/05/2014**
- Q2. How long are the runs?
- a. **On the attached site map, everything is labeled, with a grid key for distances. The cable needed for outside use is Underground Outside Plant (OSP), inside anything over 50feet needs to be OS1/OS2**
- Q3. How long are the distances (or average distances) from the man holes to the communications closet inside the buildings?
- a. **The contractor needs to measure.... So if you think you need a site visit to do this, please let me know on or before December 29, 2014 so that I can schedule one for all that need it on another amendment.**
- Q4. Are all the communications closets in the basement of the buildings?
- a. **Yes, all closets are in all the Basements.**
- Q5. When going through the buildings to pull the cable, is Infection Control required? Control Cubes? HIPPA Tents? (especially in patient buildings)
- a. **Inner Duct and Conduit is in place, the only place needing to use inner Duct is buildings 19, 20, 21, and 22 which all come out of the same IT closet coming off the manhole. 81 Building is the Chapel, and it feeds through building 9 underground. No Infection Control cubes or tents will be required, everything is in conduit.**
- Q6. Are there any specs on equipment for the interconnect housing in the closets?
- a. **Yes, contractor is to provide patch panel, along with the cables from question #2, and on the racks that are from question #7.**
- Q7. Is there space on existing racks to terminate the fiber or will we need to install racks? If racks currently exist is there adequate space to place the fiber?
- a. **No, new racks will need to be installed for the fiber.**
- Q8. Is there a Building 81, and what about the lines from building 33 to building 80?
- a. **Yes, travel through building 33 to 80, and there is no building 81.**

See attached document: P09 Fiber Optic Blue Print of Facility.