

DOOR SIZES		
MARK	WIDTH	HEIGHT
A	3'-0" (914.4 mm)	7'-0" (2133.6 mm)
B	4'-0" (1219.2 mm)	7'-0" (2133.6 mm)

FRAME TYPE	
#	MATERIAL
1	HOLLOW METAL

FIRE RATING	
MARK	UL
A	2 HOUR
B	1 ½ HOUR
C	45 MINUTES
20	20 MINUTES

DOOR TYPE	
#	MATERIAL
1	WOOD
2	METAL

#### DOOR MODIFICATIONS:

A	LAMINATED GLASS
ADO	AUTOMATIC DOOR OPERATOR (SWING OR SLIDE)
ALK	AUDIBLE ALARM (ON EGRESS)
CL	STAND-ALONE CARD READER LOCK
CR	CARD READER
D	DOUBLE GLAZED TEMPERED GLASS
DE	DELAYED EGRESS
DPS	DOOR POSITION SWITCH (DOOR CONTACT)
H	ELECTRIC HOLD-OPEN (WALL-MAGNET PREFERRED, OR ELECTRO-MECHANICAL CLOSER-HOLDER)
IC	INTERCOM
ID	INTEGRATED DOOR ASSEMBLY
IL	INTERLOCKED

L	LOUVER
LL	LEAD-LINED DOORS
M	MECHANICAL SEAL FOR LIGHT PROOF & SOUND RETARDING DOOR
P	PANIC HARDWARE
PB	STAND-ALONE PUSHBUTTON LOCK
RF	RADIOFREQUENCY SHIELDED DOOR
RR	REMOTE RELEASE BUTTON
STC	ACOUSTIC DOOR ASSEMBLY (INDICATE STC RATING #)
T	TEMPERED GLASS
TL	TIMER LOCK (ELECTRIC LOCK/UNLOCK OF DOOR USING ELECTRIC TIMER)
U	UNDERCUT 1" [25mm]
V	LEAD GLASS
W	WIRED GLASS



#### NOTES:

A. REFER TO SHEET AE101 FOR NEW DOOR AND WALL LOCATIONS.

#### NOTES:


- ALL DOORS SHALL BE FLUSH - 1 ¾" [44mm] THICK UNLESS NOTED OTHERWISE.
- ODD NUMBERS ARE WOOD; EVEN NUMBERS ARE METAL.
- DOUBLE LETTERS ARE EQUIVALENT TO DOUBLE DOORS IN OPENING.
- REFER TO DETAIL C1 THIS SHEET FOR ALL DOOR JAMB DETAILS
- REFER TO DETAIL C2 THIS SHEET FOR ALL DOOR HEAD DETAILS
- REFER TO DETAIL C3 THIS SHEET FOR ALL DOUBLE DOOR SILL DETAILS

#### DOOR SYMBOL




\*\*CONTRACTOR SHALL VERIFY PARTITION THICKNESS PRIOR TO DETERMINING FRAME THROAT SIZE


**C1 DOOR JAMB DETAIL**  
SCALE: 3' = 1'-0"



**C2 DOOR HEAD DETAIL**  
SCALE: 3' = 1'-0"



**C3 DOOR SILL DETAIL**  
SCALE: 3' = 1'-0"





\* UL DESIGN NO. U411 (2 HOUR)

**E1 PARTITION TYPES**  
SCALE: 1' = 1'-0"

#### CONSULTANTS:

#### ARCHITECT/ENGINEERS:



200 Envoy Circle #201, Louisville KY 40299 - PH: 502.339.8511 - www.paradigmusa.com

Drawing Title  
ARCHITECTURAL WALL AND DOOR DETAILS

Approved Project Director

Project Title  
REPLACE FIRE PUMP BUILDING 1

Location  
RICHARD L. ROUBEUSH VAMC  
1481 W 10TH STREET, INDIANAPOLIS IN 46202

Date  
12-2-2014

Checked  
JCP

Drawn  
LSS

Project Number  
583-13-121

Building Number  
1

Drawing Number  
AE501

FULLY SPRINKLERED  
BID DOCUMENTS - FOR CONSTRUCTION

Office of  
Construction  
and Facilities  
Management

