


**F1 PARTIAL BASEMENT PLAN**  
SCALE: 1/4" = 1'-0"

[illegible]

CONSULTANTS:



ARCHITECT/ENGINEERS:





200 Envoy Circle #201, Louisville KY 40299 - PH: 502.339.8511 - [www.paradigmusa.com](http://www.paradigmusa.com)

**KEY NOTES:**

1. REMOVE EXISTING FIRE PUMP CONTROLLER.
2. REMOVE EXISTING JOCKEY PUMP CONTROLLER AND FEEDER ORIGINATING FROM ROOM D-B009. CONCRETE-EMBEDDED RACEWAY ABOVE SHALL REMAIN. RELOCATE BUILDING MANAGEMENT SYSTEM CURRENT TRANSFORMERS AND ASSOCIATED WIRING TO NEW CONTROLLER.
3. DISCONNECT EXISTING 75HP FIRE PUMP MOTOR. REMOVE FEEDER ORIGINATING FROM FIRE PUMP CONTROLLER.
4. DISCONNECT EXISTING 5HP JOCKEY PUMP MOTOR. REMOVE FEEDER ORIGINATING FROM JOCKEY PUMP CONTROLLER.
5. REMOVE EXISTING FIRE PUMP NORMAL POWER DISCONNECT AND EXISTING TRANSFER SWITCH 'ATS1D4'. REMOVE OVERHEAD FEEDERS ORIGINATING FROM SWITCHBOARD 'BMSD' AND PANEL 'DBHDP2'. REMOVE FEEDER TO FIRE PUMP CONTROLLER IN ROOM D-B011. REFER TO PHOTO F5 ON THIS SHEET.
6. REPLACE EIGHT (8) EXISTING FIRE ALARM MONITOR MODULES WITH NEW SIEMENS MODULES. REFER TO SHEET EP101 AND PHOTO F5/EP901.
7. DISCONNECT EXISTING REFRIGERATION EQUIPMENT, ASSOCIATED 60-AMP, 3-POLE, 240-VOLT DISCONNECT SWITCH, AND CONTACTOR. REMOVE ASSOCIATED BRANCH CIRCUIT BACK TO PANEL 'DBLE1' IN ROOM D-B003.
8. REWORK OVERHEAD FEEDER TO PANEL 'DSMLT1' FROM THIS POINT TO NEW PANEL LOCATION. REFER TO SHEET EP101. PROPERLY SUPPORT CONDUIT IN ACCORDANCE WITH NEC. THE 125-AMP, 480/277-VOLT PANEL IS FED FROM PANEL 'DBHN1' IN ROOM D-B003.
9. REMOVE AND RELOCATE EXISTING SURVEILLANCE CAMERA. REFER TO SHEET EP101 FOR NEW LOCATION. EXTEND CABLE FROM JUNCTION BOX LOCATED ABOVE. FURNISH AND INSTALL COVER ON EXISTING 4-INCH SQUARE BOX.
10. REMOVE AND RELOCATE SINGLE-POLE SWITCH AND CONNECTIONS TO 'UH-10'. REFER TO EP101.
11. REMOVE AND RELOCATE EXISTING SNOW MELT CONTACTORS (18"x18"x7" ENCLOSURE) AND SNOW MELT CONTROLLER. THE EXISTING 8"x8"x36" PULL BOX WILL REMAIN AND BE UTILIZED TO EXTEND CONDUCTORS TO NEW LOCATION. RELOCATE EXISTING SNOW MELT CONTROLLER DISCONNECT. REFER TO EP101. REFER TO PHOTOS ON EP901.


NOTES:

- C. REFER TO SHEET E-001 FOR LEGEND, ABBREVIATIONS, AND GENERAL NOTES.
- B. REFER TO SHEET ED101 FOR DEMOLITION OF LIGHTING AND LIGHTING CONTROLS.
- C. REFER TO SHEET EP901 FOR PHOTOS OF EXISTING CONDITIONS.
- D. ALL EQUIPMENT IS EXISTING TO REMAIN UNLESS DENOTED AS NEW OR DESIGNATED TO BE REPLACED OR ALTERED (REFER TO KEY NOTES).
- E. ALL CONDUIT AND WIRING FOR THE INDICATED REMOVED EQUIPMENT SHALL BE COMPLETELY REMOVED AND THE CIRCUIT BROUGHT BACK TO THE POINT OF ORIGIN UNLESS INDICATED TO BE REUSED ON THE NEW WORK PLANS.
- F. CARE SHOULD BE TAKEN BY ALL CONTRACTORS TO AVOID DAMAGING OR DISTURBING EXISTING CONSTRUCTION THAT IS TO REMAIN. CONTRACTORS SHALL BE RESPONSIBLE FOR MAKING ANY REPAIRS NECESSARY TO RECTIFY DAMAGE AND RESTORE EXISTING CONSTRUCTION TO UNDAMAGED STATE UPON COMPLETION OF WORK AT NO EXPENSE TO OWNER.
- G. ALL CONTRACTORS SHALL THOROUGHLY FAMILIARIZE THEMSELVES WITH ALL PROJECT DRAWINGS AND DETAILS PRIOR TO BEGINNING CONSTRUCTION FOR COORDINATION OF ALL DEMOLITION WORK FOR EACH RESPECTIVE TRADE.
- H. UNLESS NOTED, OR OTHERWISE SHOWN OR SPECIFIED, ALL MATERIALS AND EQUIPMENT REMOVED OR DEMOLISHED (EXCEPT THAT WHICH IS TO BE SALVAGED OR RELOCATED) AS DIRECTED BY DRAWINGS AND SPECIFICATIONS SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE DISPOSED OF LEGALLY.
- I. CONTRACTOR SHALL VISIT THE SITE TO DETERMINE THE SCOPE OF ELECTRICAL DEMOLITION WORK.
- J. COORDINATE ALL DEMOLITION OPERATIONS WITH THE 01 00 00 SPECIFICATION AND THE OWNER AND PROCURE PRIOR APPROVAL FOR ALL DEMOLITION PROCEDURES, INCLUDING: USE OF BUILDING FACILITIES, PLACEMENT OF DUMPSTERS, REFUSE REMOVAL, AND PHASING.
- K. AFTER DEMOLITION, ALL ABANDONED PENETRATIONS SHALL BE PATCHED AND FIRE PROTECTED ACCORDING TO CODE AND SPECIFICATIONS.
- L. DISCONNECT FIRE ALARM MODULES FROM EXISTING VALVE TAMPER SWITCHES. REFER TO FIRE PROTECTION SHEETS FX401 AND FX402.
- M. RENOVATION NOTATIONS:
  - (R) LOCATION OF RELOCATED DEVICE OR EQUIPMENT
  - (RR) REMOVE AND RELOCATE EXISTING DEVICE OR EQUIPMENT
  - (RX) REMOVE EXISTING DEVICE OR EQUIPMENT
  - (X) EXISTING DEVICE OR EQUIPMENT TO REMAIN
  - (XR) EXISTING DEVICE OR EQUIPMENT TO BE REMOVED AND REPLACED AT SAME LOCATION



**KEY PLAN**  
**NOT TO SCALE**

FULLY SPRINKLERED  
S - FOR CONSTRUCTION

Drawing Title <b>ELECTRICAL DEMOLITION PLAN</b>		Project Title <b>REPLACE FIRE PUMP BUILDING 1</b>		Project Number <b>583-13-121</b>		Office of Construction and Facilities Management
Approved Project Director		Location <b>RICHARD L. ROUDEBUSH VAMC 468 W 15TH STREET, INDIANAPOLIS IN 46202</b>		Building Number <b>1</b>		
				Drawing Number <b>ED101</b>		
Date <b>12-2-2014</b>		Checked <b>BAM</b>		Drawn <b>BAM</b>		 Department of Veterans Affairs