




three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one quarter inch = one foot
one eighth inch = one foot




D1 PARTIAL BASEMENT PLAN - DEMOLITION
SCALE 1/4" = 1'-0"



F1 EXISTING FLEX DUCT
NOT TO SCALE




F3 EXISTING UNIT HEATER
NOT TO SCALE






F5 EXISTING COMPRESSOR
NOT TO SCALE

- NOTES:**
- A. REFER TO SHEET M-001 FOR LEGEND, ABBREVIATIONS, AND GENERAL NOTES.
 - B. ALL EQUIPMENT IS EXISTING TO REMAIN UNLESS DENOTED AS NEW OR DESIGNATED TO BE REPLACED OR ALTERED (REFER TO KEY NOTES).
- KEY NOTES:**
1. DISCONNECT EXISTING FLEX DUCT FROM EXISTING METAL OVAL DUCT. PATCH METAL DUCT WHERE FLEX DUCT IS REMOVED. REMOVE FLEX DUCT TO LOCATION NEAR WALL FOR NEW DUCT CONNECTION. REFER TO PHOTO F1/MD101.
 2. REMOVE SECTION OF DUCT FOR INSTALLATION OF NEW FIRE DAMPER.
 3. DISCONNECT EXISTING REFRIGERATION SYSTEM AND TURN OVER TO THE VA. RECOVER ALL REFRIGERANT FROM EXISTING SYSTEM AND REMOVE EXISTING UNIT AND PIPE AS INDICATED. REFER TO PHOTO F5/MD101.
 4. DISCONNECT EXISTING UNIT HEATER AND MOVE TO NEW LOCATION AS INDICATED ON SHEET MH101. REFER TO PHOTO F3/MD101.



KEY PLAN
NOT TO SCALE

Revisions	Date	CONSULTANTS:		ARCHITECT/ENGINEERS:  200 Envoy Circle #201, Louisville KY 40299 - PH: 502.339.8511 - www.paradigmusa.com	Drawing Title MECHANICAL DEMOLITION PLAN	Project Title REPLACE FIRE PUMP BUILDING 1	Project Number 583-13-121	Office of Construction and Facilities Management 
					Approved Project Director	Location RICHARD L. ROUEBUSH VAMC 1481 W 10TH STREET, INDIANAPOLIS IN 46202	Date 12-2-2014	

VA FORM 08-6231