



1010 Kings Highway South
Building Two – 2nd Floor
Cherry Hill, NJ 08034

Phone: 856-429-4000
Fax: 856-429-5002
E-mail: office@miller-remick.com

Request for Information

Contractor RFI No.:

Request Date:

1/12/15

Contractor/Supplier: **Welch Construction**

M-R RFI Log No.: **11**

Response Date:

01/16/15

VA Project No.: **528-13-C-0179**

M-R Project No.:

3-0499-0046

Project Name: **Renovate 6B Ward Syracuse VAMC**

RFI: (Attachments ☐ Yes ☒ No)

Q-I haven't been able to find any manufacturer making the fixture described using 6 each 32 watt T8 lamps. Can you find out if there is a design make and model number for this fixture? (Type A1 over bed fixture)

Thank you,

A-Multi Med T8 light fixture is not available on the market as far as we can determine. As a result, please utilize a LED version, HE Williams type AMDG24LEDPH50...w/ low voltage lighting controller or equal.

Alex Johnson
VA Syracuse

DOCUMENT1

Reviewed By:

Sam Tibi, P.E.