



NOTES:

1. MAINTAIN MINIMUM CLEARANCE OF 8'-0" AFF TO BOTTOM OF DUCTWORK AND PIPING. CONTRACTOR SHALL FIELD ROUTE, VALVES, CONTROLS, EQUIPMENT, ETC. SHALL REMAIN EASILY ACCESSIBLE. DO NOT OBSTRUCT COIL PULLS, OR ROUTE PIPING DIRECTLY ABOVE ELECT. OR CONTROL PANELS, ELECTRIC EQUIPMENT OR VFD'S.

M SEVENTH FLOOR - PARTIAL PLAN
SCALE: 1/8" = 1'-0"

three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one quarter inch = one foot
one eighth inch = one foot

NO	ISSUE FOR CONSTRUCTION	REVISIONS	DATE

CONSULTANTS:

WARNING: This warning is required to be included on this document under New York State Education Law, Article 145, Section 7209, Sub-paragraph 2. It is a violation of the aforementioned law for any person, unless acting under the direction of a licensed professional engineer or land surveyor, to alter any portion of the design set forth on this document. If any item of the design set forth in this document is altered, the altering engineer or land surveyor shall affix to the item his/her seal and the notation "altered by" followed by his/her signature and the date of such alteration and a specific description of the alteration.

David E. Kurten, Jr
092848

ARCHITECT/ENGINEERS:

HDR

Henningson, Durham & Richardson, Architecture and Engineering, P.C.
500 Seventh Ave, 11th Floor, New York, NY 10018 . 212-904-1212

Drawing Title
MECHANICAL SEVENTH FLOOR PLAN

Approved: Project Director
-
-

Project Title
**VA NY HARBOR HEALTHCARE SYSTEM
MANHATTAN CAMPUS GROUND FLOOR PHASE IB
STERILE PROCESSING SUITE**

Project Number
219359

Building Number
6

Location
423 E 23RD STREET, NEW YORK, NY 10010 -

Date
02/18/2014

Checked
DS

Drawn
TJ

Drawing Number
MH170

Dwg. of

FULLY SPRINKLERED

Office of
Construction
and Facilities
Management

VA U.S. Department
of Veterans Affairs