

three inches = one foot
6"

- one and one half inches = one foot

- one inch = one foot
6" 0

- three quarters inch = one foot

- one half inch = one foot

- three eighths inch = one foot

- one quarter inch = one foot

- one eighth inch = one foot
-
- 0 4 8 16

A

- B

C

- D

F

- | HVAC DESIGN DATA | | | | | | | |
|----------------------------|---------|---------|------|--------|---------|------|--------------------------------|
| DESIGN CONDITIONS | SUMMER | | | WINTER | | | LOWEST AVERAGE ANNUAL DEWPOINT |
| | DB TEMP | WB TEMP | % RH | TEMP | DP TEMP | % RH | |
| OUTDOOR DESIGN CONDITIONS | 93 °F | 75.6 °F | 45 | 26 °F | 22 °F | 50 | 15 °F |
| DRY LABORATORY | 70 °F | 65.5 °F | 60 | 70 °F | 28 °F | 20 | |
| INTENSIVE CARE UNITS (ICU) | 75 °F | 65.5 °F | 60 | 70 °F | 28 °F | 20 | |
| AUDITORIUM | 75 °F | 65.5 °F | 60 | 70 °F | | | |

Office of
Facilities
Management

