



- 1 ROUTE HUMIDIFIER DRAIN TO NEAREST FLOOR DRAIN.
- 2 ROUTE HUMIDIFIER DRAIN TO NEAREST ROOF DRAIN.
- 3 PROVIDE ADAPTER CURB WITH SERVICE PLATFORM AND HANDRAILS TO FIT OVER EXISTING AHU-14 ROOF CURB.
- 4 MOUNT UNIT IN AUXILIARY DRIP PAN.
- 5 PROVIDE NEW 4" HOUSEKEEPING PAD

		CONSULTANTS:				PROJECT MANAGER:		Project Number 2013121		Scale 1/2" = 1'-0"		Drawing Title MECHANICAL SECTIONS - AHUS		Project Title REPLACE AIR HANDLING UNITS 3, 14, & 34		VA Project Number 246-13-C-0106		Office of Facilities Management			
						 <p>Raleigh, NC Indianapolis, IN Philadelphia, PA Fort Collins, CO Virginia Beach, VA (919) 858-7420 www.acg-pa.com NC License # C-1845</p>						Approved: Project Director		Location 2300 RAMSEY STREET, FAYETTEVILLE, NC 28301		Building Number 1 AND 3				Drawing Number M-301	
Amended Per Owner's Comments No Rev Clouds		10/17/2014												Date 08/28/2014		Checked DJR				Drawn SPG	
Revisions		Date																Dwg. 9 of 18		 Department of Veterans Affairs	