



REQUEST FOR INFORMATION

TO: MILA BEAVER

FROM: **Libby Smith**

COMPANY:

Miller-Remick

DATE:

January 21, 2015

PROJECT NAME:

VA Medical Syracuse renovate 6B Ward

SPECIFICATION SECTION: 27 52 23 NURSE CALL

SENDER'S REFERENCE NUMBER: SU035650

RE: Personal Wireless Communicator Paragraph 2.4.5 Pg 25

REQUEST:

Please respond ASAP. Thank you.

Please clarify the wireless transport that will be allowed into the facility.

DECT (dedicated closed wireless network) or Wi-Fi (VA provided access points)

A DECT solution would entirely be provided by Ronco, if Wi-Fi we would expect the wireless infrastructure to be provided and configured by others.

Treat this Q/A as RFI #12

ANS: No wireless communicator system or system interface is required to be provided by nurse call provider or by anyone on this contract.

Please eliminate sections 2.4.5 and 2.4.6 in spec section 27 52 23

Alex Johnson

COR