

GENERAL ELECTRICAL DEMOLITION NOTES: (THIS SHEET ONLY)


- | | | | |
|-----|--|------|--|
| 2.0 | DRAWINGS INDICATE APPROXIMATE LOCATION AND QUANTITY OF TRANSFORMERS, VFDS, STARTERS, ETC. TO BE REMOVED. THE ELECTRICAL SUBCONTRACTOR SHALL VERIFY LOCATION AND QUANTITY OF ITEMS TO BE REMOVED. NO ALLOWANCE WILL BE MADE BECAUSE OF THE ELECTRICAL SUBCONTRACTOR'S UNFAMILIARITY WITH THESE DETAILS. | 6.0 | HOLELS AND DAMAGED AREAS CAUSED BY REMOVAL OF ANY OF THE ABOVE ITEMS AND WHICH ARE NOT CONCEALED BY NEW CONSTRUCTION SHALL BE REPAIRED TO MATCH EXISTING SURFACES. IN ADDITION, OPENINGS OF THE TYPE OF THE REMOVED ITEMS THROUGH FIRE RESISTANCE RATED WALLS SHALL BE FIRE STOPPED. |
| 2.0 | ALL SALVAGE WILL REMAIN THE PROPERTY OF THE OWNER AND SHALL BE DELIVERED BY THE CONTRACTOR TO A LOCATION AS DIRECTED. ANY SALVAGE NOT DESIRED BY THE OWNER SHALL BECOME THE PROPERTY OF THE CONTRACTOR AND SHALL BE REMOVED FROM THE PREMISES. | 7.0 | WHERE CONDUIT AND CONDUCTORS ARE INDICATED TO BE REMOVED CONDUIT SHALL BE REMOVED TO POINT OF CONCEALMENT AND WIRING REMOVED ENTIRELY. PROVIDE BLANK COVERPLATES WHERE REQUIRED. |
| 3.0 | ALL VFDS, COMBINATION STARTER / DISCONNECT SWITCHES, ETC. SCHEDULED FOR DEMOLITION SHALL HAVE THEIR ASSOCIATED CIRCUITRY REMOVED BACK TO THE PROTECTIVE DEVICE IN A PANELBOARD, ETC. EXCEPT AS MENTIONED IN 4.0 AND 5.0, THE PROTECTIVE DEVICE SHALL REMAIN AN INTEGRAL PART OF THE PANELBOARD AND BE INDICATED ON THE PANEL DIRECTORY AS A SPARE OR REUSED FOR NEW CIRCUITRY. | 8.0 | BLANK COVERPLATES AND ALL UNBUILT OPENINGS IN BOXES, RACKWAYS, AUXILIARY CUTTERS, CABINETS, EQUIPMENT CASES AND ENCLOSURES SHALL BE CLOSED OFF TO PROVIDE SUBSTANTIALLY EQUIVALENT TO THE WALLS OF THE EQUIPMENT (REFER TO NEC). |
| 4.0 | IF A CONDUIT RUN IS EXPOSED OR A SURFACE RACEWAY LEFT WITHOUT A MOUNTING SURFACE DUE TO THE REMOVAL OF A PARTITION, THE CONDUIT SHALL BE REROUTED AS ACCEPTABLE TO THE OWNER/ARCHITECT. | 9.0 | IF A CONDUIT RUN IS EXPOSED OR A SURFACE RACEWAY LEFT WITHOUT A MOUNTING SURFACE DUE TO THE REMOVAL OF A PARTITION, THE CONDUIT SHALL BE REROUTED AS ACCEPTABLE TO THE OWNER/ARCHITECT. |
| 1.1 | ASSOCIATED CIRCUITRY IS DEFINED AS ALL WIRE, CONDUIT, DEVICES, DEVICE BOXES, WIRING DEVICES, COVER PLATES, ETC. ASSOCIATED WITH THE ITEM SCHEDULED FOR REMOVAL. | 10.0 | ELECTRICAL EQUIPMENT, OUTLETS AND/OR DEVICES THAT ARE TO BE RELOCATED BUT WERE DAMAGED WHEN REMOVED SHALL BE REPAIRED, RESTORED OR REPLACED AT THE DISCRETION OF THE APPROVAL OF THE OWNER. THE CONTRACTOR SHALL NOTIFY THE OWNER/ARCHITECT/ENGINEER OF ANY ELECTRICAL EQUIPMENT, OUTLETS AND/OR DEVICES WHICH ARE INDICATED AS RELOCATED BUT ARE FOUND TO BE UNSALVAGEABLE. |
| 3.2 | CONDUIT FOR ITEMS SCHEDULED FOR REMOVAL AND IN ACCESSIBLE AREAS SHALL BE SAFELY MANAGED AND SEALED OR OTHERWISE TERMINATED IN A EMPHATIC MANOR ACCEPTABLE TO THE OWNER. | 11.0 | ALL EXISTING FIRE ALARM DEVICES, CONDUIT AND WIRING ASSOCIATED WITH EQUIPMENT SCHEDULED FOR DEMOLITION, SHALL BE REMOVED IN ITS ENTIRETY. INSTALL NEW CONDUCTORS AND DEVICES AS PER SPECIFICATIONS AND COMPATIBLE WITH EXISTING FIRE ALARM SYSTEM. |
| 4.0 | ELECTRICAL CIRCUITS WITH A PORTION OF THE LOAD REMOVED SHALL HAVE THE REMOVED LOADS ASSOCIATED CIRCUITRY TERMINATED IN SUCH A MANNER THAT THE REMAINING LOAD REMAINS ACTIVE AND IN FIRST CLASS OPERATING CONDITION. | | |
| 5.0 | THE ELECTRICAL SUBCONTRACTOR SHALL CONSULT THE SPECIFICATIONS FOR FURTHER INFORMATION. | | |

DEMOLITION NOTES: (THIS SHEET ONLY)





- ① EXISTING DISCONNECT SWITCH, WIRING, AND CONDUIT TO BE REMOVED IN ITS ENTIRETY.
THE CORRIDOR NEXT TO MAIN KITCHEN.
- ② EXISTING DUCT-MOUNTED SMOKE DETECTORS, WIRING, AND ASSOCIATED CONDUIT TO BE REMOVED IN ITS ENTIRETY.
- ③ APPROXIMATE LOCATION OF EXISTING ELECTRICAL PANEL "3XNA" LOCATED ON THE THIRD LEVEL IN CORRIDOR NEXT TO MAIN KITCHEN. THIS PANEL IS EXISTING TO REMAIN.

**BLDG. 11 - 4TH FLR. (ANNEX)
MECHANICAL ROOMS**

SCALE: 1/4" = 1'-0"



KEY PLAN

		CONSULTANTS:		ARCHITECT/ENGINEERS:		Approved: Assistant Director			Approved: Chief of Staff			Approved: Chief, Engineering			Drawing Title			Project Name			Project Number			Office of Construction and Facilities Management  Department of Veterans Affairs					
		 Goetting & Associates, Inc. 12710 Research Blvd. Suite 355 Austin, Texas 78759 512/416-1654 FAX: 512/416-7547		 ADRIAN LOZANO 84720 CIVIL ENGINEER TIG GOETTING, INC. 09-15-13 P-803		 RH SHACKELFORD, INC SDBYSB			Approved: Service Chief			Approved: Service Chief			Approved: Service Chief			ELECTRICAL DEMOLITION BUILDING 11 - FOURTH FLR POWER PLAN - MECH RMS			KD AIR HANDLER REPLACEMENT (AHU) PROJECT - PHASE II						671A4-09-119		
						Approved: Chief, Bio-Med			Approved: Chief, EMS			Approved: Chief, Infection Control			Location						Date								
						Approved: Chief, IT			Approved: Chief, M&O			Approved: Chief, Police			Kerrville Veterans Hospital Veterans Affairs 2600 Memorial Blvd. Kerrville, TX 78028			Building Number			09/13/12								
Revisions:		Date							Approved: Chief, Safety			Approved: Chief			Approved: Chief			Checked RTO			Drawing Number			11-ED102					
																		Dwg. of											