



GENERAL NOTES: (THIS SHEET ONLY)

1. REFER TO MECHANICAL AND PLUMBING EQUIPMENT CONNECTION SCHEDULE ON SHEET EP601 REGARDING INFORMATION ON ALL TAGGED EQUIPMENT.
2. THE CONTRACTOR SHALL UTILIZE EXISTING FIRE ALARM CIRCUITS IN EACH MECHANICAL ROOM TO SERVE NEW SMOKE AND DUCT MOUNTED SMOKE DETECTORS.

KEYED NOTES: (THIS SHEET ONLY)

1. PROVIDE 120-VOLT POWER FOR AIR HANDLING UNIT LIGHTS AND PLUGS. THE CONTRACTOR SHALL CONNECT TO EXISTING 120-VOLT GENERAL BRANCH CIRCUIT SERVING THIS AREA.



NORTH

1 BLDG. 11 - 4TH FLR. (ANNEX) MECHANICAL ROOMS

SCALE: 1/4" = 1'-0"



KEY PLAN

Revisions:	Date

CONSULTANTS:

TTG Goetting

Goetting & Associates, Inc.
12710 Research Blvd. Suite 355
Austin, Texas 78759
512/416-1654 FAX:512/416-7547

STATE OF TEXAS
ADRIAN LOZANO
84720
LICENSED
PROFESSIONAL ENGINEER

TTG GOETTING, INC. F-903 07-15-13

ARCHITECT/ENGINEERS:

RH SHACKELFORD, INC
SDVOSB

Approved: Assistant Director	Approved: Chief of Staff	Approved: Chief, Engineering
Approved: Service Chief	Approved: Service Chief	Approved: Service Chief
Approved: Chief, Bio-Med	Approved: Chief, EMS	Approved: Chief, Infection Control
Approved: Chief, IT	Approved: Chief, M&O	Approved: Chief, Police
Approved: Chief, Safety	Approved: Chief	Approved: Chief

Drawing Title
ELECTRICAL NEW WORK
BUILDING 11 - FOURTH FLOOR
POWER PLAN - MECH RMS

Location
Kerrville Veterans Hospital
Veterans Affairs
2600 Memorial Blvd.
Kerrville, TX 78028

Project Name
KD AIR HANDLER REPLACEMENT (AHU) PROJECT - PHASE II

Building Number | Checked RTO | Drawn RTO

Project Number 671A4-09-119

Date 09/13/12

Drawing Number 11-EP402

Dwg. of

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231