

AREAS SAMPLED JANUARY 2003:  
NON-ASBESTOS-CONTAINING MATERIALS

- VF02 Gray Sheet Vinyl Flooring
- VF03 Light Gray/Dark Gray and White Sheet Vinyl Flooring
- 12FT06 12"x12" White Floor Tile and Mastic
- 12FT07 12"x12" Light Gray Marble Floor Tile and Mastic
- 12FT08 12"x12" Gray w/White Floor Tile and Mastic
- 12FT09 12"x12" Taupe Floor Tile and Mastic
- 12FT10 12"x12" Dark Gray Floor Tile and Mastic
- WC01 Window Caulking
- PC01 Plaster Ceiling
- PW01 Plaster Wall
- SF02 Spray-On Fireproofing (Gray)
- CB01 Black Covebase Mastic
- CB03 Taupe Covebase Mastic
- CB04 Brown Covebase Mastic
- CB05 Gray Covebase Mastic
- 2SC01 2'x2' Swirl Ceiling Panel
- 2SC02 2'x2' Wormhole/Pinhole (new) Ceiling Panel
- 2SC03 2'x2' Wormhole/Pinhole (old-Large) Ceiling Panel
- 2SC04 2'x2' Wormhole/Pinhole (small) Ceiling Panel
- 2SC06 2'x2' Rough Finish Ceiling Panel
- DM01 Tan Duct Mastic
- PP03 Red Pipe Putty (Firestop)
- GW01 Drywall Joint Compound


SAMPLE IDENTIFICATION

- 9-WC01-EXTERIOR-01 NON-ASBESTOS-CONTAINING MATERIAL

DESCRIPTION	LOCATION
FT01-12"x12" TAN W/ BROWN FLECK FT/MASTIC	1099, 1026, 1027, 1028, 1156, 1154, 1150, 1149B, 1149A, 1149, 1147, 1142, 1141, 1136
FT02-TAN FT/BLACK MASTIC	1026, 1027, 1028
BLACK MASTIC	1054B, 1051, 1049, 1048, 1047

Homogenous Area	Sample Number	Sample Description	Locations	Results
FT01	22-2-1-01	Tan with Brown Fleck FT / Mastic	RM G002 NW end	3% CH-tile, 10% CH-mastic
	22-2-1-02		RM 1141 N End	
	22-2-1-03		RM 1150 E Wall	
	22-2-1-04	Tan FT / Black Mastic	RM 1026 Middle	1%-CH-tile
	22-2-1-05		RM 1027 S End	
	22-2-1-06		RM 1029 (Black FT) Middle	
FT02	22-2-1-07	Black Mastic	RM 1051 B Doorway	3% CH-mastic
	22-2-1-08		RM 1047 Doorway	
	22-2-1-09		RM 1054B Doorway	

BULK SAMPLE LOCATIONS  
BUILDING 2 - 1ST FLOOR AND TUNNEL TO BUILDING 5  
VA MEDICAL CENTER  
SALISBURY, NORTH CAROLINA



**HGS ENGINEERING, INC.**

1121 NOBLE STREET  
ANNISTON, ALABAMA 36201