


AREAS SAMPLED JANUARY 2003:
NON-ASBESTOS-CONTAINING MATERIALS

- 12FT01 12"x12" WHITE FLOOR TILE AND MASTIC
- 12FT04 12"x12" BLUE FLOOR TILE AND MASTIC
- 12FT09 12"x12" WHITE WITH GRAY FLOOR TILE AND MASTIC
- 12FT13 12"x12" DARK PINK FLOOR TILE AND MASTIC
- 12FT14 12"x12" LIGHT PINK FLOOR TILE AND MASTIC
- 12FT15 12"x12" LIGHT BLUE MARBLE FLOOR TILE AND MASTIC
- WC01 WINDOW CAULKING
- PC01 PLASTER CEILING
- PW01 PLASTER WALL
- CB01 BLACK COVEBASE MASTIC
- CB04 DARK TAN COVEBASE MASTIC
- 2SC02 2'x2' WORMHOLE/PINHOLE CEILING PANEL (NEW)
- 2SC03 2'x2' SWIRL CEILING PANEL
- 2SC06 2'x2' SMALL WORMHOLE/PINHOLE CEILING PANEL
- 2SC07 2'x2' SMOOTH CEILING PANEL
- GW01 DRYWALL JOINT COMPOUND

SAMPLE IDENTIFICATION

- 9-WC01-EXTERIOR-01 NON-ASBESTOS-CONTAINING MATERIAL
- ASBESTOS-CONTAINING MATERIAL

BULK SAMPLE LOCATIONS
BUILDING 3 - 3RD FLOOR
VA MEDICAL CENTER
SALISBURY, NORTH CAROLINA



HGS ENGINEERING, INC.
1121 NOBLE STREET
ANNISTON, ALABAMA 36201