

SYSTEM NOTES:

1. FUEL FILTRATION SET IS ENERGIZED BASED UPON PROGRAMMED SCHEDULE.

GENERAL NOTES:

A. COORDINATE ALL REQUIREMENTS WITH ELECTRICAL CONTRACTOR, OWNER, AND GENERAL CONTRACTOR.

B. FILTRATION SET CONTROLS SHALL BE PROGRAMMED TO OPERATE ON A SCHEDULE (ADJ.). SOLENOID VALVES SHALL OPERATE TO FILTER CONTENTS OF ONE BASE TANK AT ANY ONE TIME.

C. FILTRATION SET CONTROLS SHALL HAVE THE CAPABILITY TO FILL ANY TANK FROM ANY OTHER TANK.

1 / P501 **FUEL FILTRATION PIPING DIAGRAM**
SCALE: NONE



2 / P501 **VENT SHIELD/COLLAR INSTALLATION**
SCALE: NONE



3 / P501 **EXHAUST SHIELD/COLLAR INSTALLATION**
SCALE: NONE



KEY PLAN
SCALE: NONE

100% SUBMISSION	02-06-14
Revisions	Date

VA WESTERN NEW YORK HEALTHCARE SYSTEM
222 RICHMOND AVENUE
BATAVIA, NEW YORK 14020

ECAB engineering, p.c.
15 Schoen Place, Suite 300, Pittsford, NY 14534
Phone: (585) 641-7121
Fax: (585) 362-4175
www.ecab.com
Consultant

stamp

Architect / Engineer

CARDIOLOGY MANAGER	DATE	ENGINEERING MANAGER	DATE
INFECTION CONTROL	DATE	CARELINE MANAGER	DATE
SAFETY OFFICER	DATE	CHIEF OF STAFF	DATE

Drawing Title: DETAILS – PLUMBING

MEDICAL CENTER DIRECTOR — DATE

ASSOCIATE MEDICAL CENTER DIRECTOR — DATE

Project Title: VA BATAVIA EMERGENCY POWER UPGRADES

Building Number: 1 | Checked: AJW | Drawn: WAB

Location: V.A.M.C. BATAVIA, NEW YORK

Date: June 6, 2014

Station No.: 528-13-201

13-201-P501

Office of Facilities

Department of Veterans Affairs