


- ## NEW WORK KEYED NOTES
- | | |
|---|---|
| 1 | INSTALL 18" CORRUGATED METAL PIPE TO ALLOW WATER FLOW UNDER RAMP. BURY PIPE HALFWAY IN THE GROUND, LEAVING TOP HALF EXPOSED. SLOPE AT MINIMUM OF 1/2" PER FOOT. |
| 2 | REMOVE OR RELOCATE EXISTING HOSE BIB IF REQ'D TO AVOID NEW CONSTRUCTION. |
| 3 | SLOPE NEW CONCRETE DECK 1/8" PER FOOT AWAY FROM BUILDING. |
| 4 | DEMOLISH EXISTING PLANTER BOX WHERE CONFLICTING WITH RAMP INSTALLATION. |
| 5 | NEW ENTRANCE RAMP. SEE DWG. SB101 FOR CONSTRUCTION INFORMATION. |
| 6 | INSTALL SILT FENCE ALONG ENTIRE LENGTH OF DISTURBED AREAS ON BOTH SIDES. |
| 7 | REGRADE AS SHOWN TO ENSURE STORM WATER DRAINS AWAY FROM BUILDING IN THIS AREA. |
| 8 | CREATE SHALLOW SWALE TO ALLOW FOR STORMWATER DRAINAGE UNDER CMP. |

Project Number 598-13-110	CENTRAL ARKANSAS VETERANS AFFAIRS HEALTHCARE SYSTEM  Department of Veterans Affairs
Building Number 170	
Drawing Number CG101 Dwg. 7 of 81	

[illegible]