




REVIEW



 **ELECTRICAL SITE PLAN**  
SCALE: 1"=20'-0"

- NOTES 
1. 200A 480/277V 3 PHASE, 4 WIRE, 3 POLE, AUTOMATIC TRANSFER SWITCH.
2. 1500 KVA 480/277V 3 PHASE, 4 WIRE GENSET WITH SKID BASED DRYTANK.
3. 3000 GALLON CONVAULT DIESEL FUEL TANK.
4. 5 SETS OF 4 #600 KCMIL, 1 #250 KCMIL EGCU IN 3-1/2" CONDUIT.
5. EXTEND EXISTING FEED TO EXISTING UNIT SUBSTATION TO NEW 2000A ATS. CONTRACTOR TO MATCH EXISTING CONDUIT AND CONDUCTOR SIZE.
6. PROVIDE 5 SETS OF 4 #600 KCMIL, 1 #250 KCMIL IN 3-1/2" CONDUIT.
7. EXISTING SWITCHGEAR WITH 2000A MCB.

[illegible]


MSA

# ELECTRICAL SITE PLAN

# Veteran's Medical Office Generator Addition

## ORLANDO, FL

### Attachment 2 \_ DFAS Generator Engineering Site Plan \_



**Colwell Engineering**  
Consulting Engineers, Inc.  
Engineering Division No. 9021  
10000 Highway 100, Suite 200  
Tulsa, Oklahoma 74116  
Tel. 813-543-2823 Fax. 813-541-2448  
© 2007 ALL RIGHTS RESERVED