PANEL SCHEDULE '3D-L' (SECTION 1)

MANUFACTURER: GENERAL ELECTRIC SERIES 'A' (EXISTING)

120 / 208 VOLTS - 3 PHASE - 4 WIRE - SURFACE MOUNTED

CIR	FOR	BREAKER POLE	BREAKER TRIP	AMPERES/PHASE A		AMPERES/PHASE B		AMPERES/PHASE C		CIR	FOR	BREAKER POLE	BREAKER TRIP
1	OFFICE 3D112A	1	20	0.0	0.0	-	-	-	-	2	MED RECORDS 3D111	1	20
3	OFFICE 3D109	1	20	-	-	0.0	0.0	-	-	4	MED RECORDS 3D111	1	20
5	OFFICE 3D110	1	20	-	-	-	-	0.0	0.0	6	MED RECORDS 3D111	1	30
7	FEE SERV 3D112	1	20	0.0	0.0	-	-	-	-	8	LOUNGE 3D127	1	20
9	FEE SERV 3D112	1	20	-	-	0.0	0.0	-	-	10	STUDY 3D127A	1	20
11	CONFER 3D113	1	20	-	-	-	-	0.0	0.0	12	DICTG 3D127C	1	20
13	3D114 3D114A	1	20	0.0	0.0	-	-	-	-	14	INFO 3D125	1	20
15	CHIEF 3D114C	1	20	-	-	0.0	0.0	-	-	16	INFO 3D125	1	20
17	OFFICE 3D114C	1	20	-	-	-	-	0.0	0.0	18	TRANSCR 3D124	1	20
19	OFFICE 3D115	1	20	0.0	0.0	-	-	-	-	20	TRANSCR 3D124	1	20
21	MISCELLANEOUS	1	20	-	-	0.0	0.0	-	-	22	STATIST 3D123	1	20
23	CORRIDOR, MISC	1	20	-	-	-	-	0.0	0.0	24	STATIST 3D122	1	20
25	3D134	1	20	0.0	0.0	-	-	-	-	26	MISCELLANEOUS	1	20
27	3D134	1	20	-	-	0.0	0.0	-	-	28	DWC	1	20
29	3D135	1	20	-	-	-	-	0.0	0.0	30	LIBRARY	1	20
31	UH #33 1/20HP	1	20	0.0	0.0	-	-	-	-	32	MED LIBRARY	1	20
33	CORRIDOR	1	20	-	-	0.0	0.0	-	-	34	MEDIA LIBRARY	1	20
35	CORRIDOR	1	20	-	-	-	-	0.0	0.0	36	MEDIA LIBRARY	1	20
37	SPARE	1	20	0.0	0.0	-	-	-	-	38	XEROX RECP	1	20
39	SPACE	-	-	-	-	0.0	0.0	-	-	40	SPACE	-	-
41	SPACE	-	-	-	-	-	-	0.0	0.0	42	SPACE	-	-
				0	0	0	0	0	0				
			TOTALS	A=	0	B=	0	C=	0				

MAIN LUGS ONLY 400 AMPERES

MINIMUM AIC RATING = 22,000 AMPERES SYMMETRICAL

TOTAL CONNECTED LOAD 0.0 KVA

PANEL SCHEDULE '3D-L' (SECTION 2)

MANUFACTURER: GENERAL ELECTRIC SERIES 'A' (EXISTING)

120 / 208 VOLTS - 3 PHASE - 4 WIRE - SURFACE MOUNTED

CIR	FOR	BREAKER POLE	BREAKER TRIP	AMPERES/PHASE A		AMPERES/PHASE B		AMPERES/PHASE C		CIR	FOR	BREAKER POLE	BREAKER TRIP
43	BOOTH 29,30,31	1	20	0.0	0.0	-	-	-	-	44	COPER A	1	20
45	BOOTH 1,2,3	1	20	-	-	0.0	0.0	-	-	46	BOOTH 8,9,10	1	20
47	COPIER B	1	20	-	-	-	-	0.0	0.0	48	BOOTH 4,5,6,7	1	30
49	BOOTH 11,12,15,16	1	20	0.0	0.0	-	-	-	-	50	BOOTH10B,14	1	20
51	BOOTH 17,21,13	1	20	-	-	0.0	0.0	-	-	52	BOOTH 19,20,23,24	1	20
53	BOOTH 26,27,28	1	20	-	-	-	-	0.0	0.0	54	BOOTH 18,22,25	1	20
55	HUMIDIFIER 3D142B	1	20	0.0	0.0	-	-	-	-	56	IRM RECEPTACLE	1	20
57	IRM RECEPTACLE - 2ND FLOOR	1	20	-	-	0.0	0.0	-	-	58	IRM RECEPTACLE	1	20
59	IRM RECEPTACLE - 2ND FLOOR	1	20	-	-	-	-	0.0	0.0	60	IRM RECEPTACLE	1	20
61	IRM RECEPTACLE - 2ND FLOOR	1	20	0.0	0.0	-	-	-	-	62	IRM RECEPTACLE	1	20
63	IRM RECEPTACLE - 2ND FLOOR	1	20	-	-	0.0	0.0	-	-	64		1	20
65	SPACE	-	-	-	-	-	-	0.0	0.0	66	SPACE	-	-
67	SPACE	-	-	0.0	0.0	-	-	-	-	68	SPACE	-	-
69	SPACE	-	-	-	-	0.0	0.0	-	-	70	SPACE	-	-
71	SPACE	-	-	-	-	-	-	0.0	0.0	72	SPACE	-	-
73	SPACE	-	-	0.0	0.0	-	-	-	-	74	SPACE	-	-
75	SPACE	-	-	-	-	0.0	0.0	-	-	76	SPACE	-	-
77	SPACE	-	-	-	-	-	-	0.0	0.0	78	SPACE	-	-
79	SPACE	-	-	0.0	0.0	-	-	-	-	80	SPACE	-	-
81	SPACE	-	-	-	-	0.0	0.0	-	-	82	SPACE	-	-
83	SPACE	-	-	-	-	-	-	0.0	0.0	84	SPACE	-	-
				0	0	0	0	0	0				
			TOTALS	A=	0	B=	0	C=	0				

MAIN LUGS ONLY 400 AMPERES

MINIMUM AIC RATING = 22,000 AMPERES SYMMETRICAL

TOTAL CONNECTED LOAD 0.0 KVA

PANEL SCHEDULE '3D-H'

MANUFACTURER: GENERAL ELECTRIC SERIES 'CCB' (EXISTING)

277 / 480 VOLTS - 3 PHASE - 4 WIRE - SURFACE MOUNTED

CIR	FOR	BREAKER POLE	BREAKER TRIP	AMPERES/PHASE A		AMPERES/PHASE B		AMPERES/PHASE C		CIR	FOR	BREAKER POLE	BREAKER TRIP
	-	-	-	0.0	0.0	-	-	-	-		-	-	-
	-	-	-	-	-	0.0	0.0	-	-		-	-	-
	-	-	-	-	-	-	-	0.0	0.0		-	-	-
1	LABORATORY	1	20	0.0	0.0	-	-	-	-	2	VENTILATORY	1	20
3	LABORATORY	1	20	-	-	0.0	0.0	-	-	4	MED INFO	1	20
5	LABORATORY	1	20	-	-	-	-	0.0	0.0	6	MEDICAL RECORDS	1	20
7	CORRIDOR	1	20	0.0	0.0	-	-	-	-	8	MEDICAL RECORDS	1	20
9	SPARE	1	20	-	-	0.0	0.0	-	-	10	SERVICE BAY	1	20
11	SPARE	1	20	-	-	-	-	0.0	0.0	12	SPARE	1	20
13	SPACE	-	-	0.0	0.0	-	-	-	-	14	PANEL '3CD-H'	3	60
15	SPACE	-	-	-	-	0.0	0.0	-	-	16	----------	-	-
17	SPACE	-	-	-	-	-	-	0.0	0.0	18	----------	-	-
19	SPACE	-	-	0.0	0.0	-	-	-	-	20	SPACE	-	-
21	SPACE	-	-	-	-	0.0	0.0	-	-	22	SPACE	-	-
23	SPACE	-	-	-	-	-	-	0.0	0.0	24	SPACE	-	-
25	SPACE	-	-	0.0	0.0	-	-	-	-	26	SPACE	-	-
27	SPACE	-	-	-	-	0.0	0.0	-	-	28	SPACE	-	-
29	SPACE	-	-	-	-	-	-	0.0	0.0	30	SPACE	-	-
31	SPACE	-	-	0.0	0.0	-	-	-	-	32	INTERSTISTIAL SPACE	1	20
33	SPACE	-	-	-	-	0.0	0.0	-	-	34	INTERSTISTIAL SPACE	1	20
35	SPACE	-	-	-	-	-	-	0.0	0.0	36	INTERSTISTIAL SPACE	1	20
-	SPACE	-	-	0.0	0.0	-	-	-	-	-	SPACE	-	-
-	SPACE	-	-	-	-	0.0	0.0	-	-	-	SPACE	-	-
				0	0	0	0	0	0				
			TOTALS	A=	0	B=	0	C=	0				

MAIN LUGS ONLY 400 AMPERES

MINIMUM AIC RATING = 30,000 AMPERES SYMMETRICAL

TOTAL CONNECTED LOAD 0.0 KVA

PANEL SCHEDULE '3D-E1' (LIFE SAFTETY)

MANUFACTURER: GENERAL ELECTRIC SERIES 'CCB' (EXISTING)

277 / 480 VOLTS - 3 PHASE - 4 WIRE - SURFACE MOUNTED

CIR	FOR	BREAKER POLE	BREAKER TRIP	AMPERES/PHASE A		AMPERES/PHASE B		AMPERES/PHASE C		CIR	FOR	BREAKER POLE	BREAKER TRIP
	MAIN BREAKER	3	70	0.0	0.0	-	-	-	-		SPACE	-	-
	----------	-	-	-	-	0.0	0.0	-	-		SPACE	-	-
	----------	-	-	-	-	-	-	0.0	0.0		SPACE	-	-
1	CORRIDOR	1	20	0.0	0.0	-	-	-	-	2	EXIT SIGNS	1	20
3	EXIT SIGNS	1	20	-	-	0.0	0.0	-	-	4	CORRCIDOR	1	20
5	SERVICE BAY	1	20	-	-	-	-	0.0	0.0	6	INTERST EXIT	1	20
7	SPARE	1	20	0.0	0.0	-	-	-	-	8	INTERST LTG	1	20
9	SPARE	1	20	-	-	0.0	0.0	-	-	10	SPACE	-	-
11	SPACE	-	-	-	-	-	-	0.0	0.0	12	SPACE	-	-
13	SPACE	-	-	0.0	0.0	-	-	-	-	14	SPACE	-	-
15	SPACE	-	-	-	-	0.0	0.0	-	-	16	SPACE	-	-
17	SPACE	-	-	-	-	-	-	0.0	0.0	18	SPACE	-	-
19	SPACE	-	-	0.0	0.0	-	-	-	-	20	SPACE	-	-
21	SPACE	-	-	-	-	0.0	0.0	-	-	22	SPACE	-	-
23	SPACE	-	-	-	-	-	-	0.0	0.0	24	SPACE	-	-
25	SPACE	-	-	0.0	0.0	-	-	-	-	26	SPACE	-	-
27	SPACE	-	-	-	-	0.0	0.0	-	-	28	SPACE	-	-
29	SPACE	-	-	-	-	-	-	0.0	0.0	30	SPACE	-	-
31	SPACE	-	-	0.0	0.0	-	-	-	-	32	SPACE	-	-
33	SPACE	-	-	-	-	0.0	0.0	-	-	34	SPACE	-	-
35	SPACE	-	-	-	-	-	-	0.0	0.0	36	SPACE	-	-
				0	0	0	0	0	0				
			TOTALS	A=	0	B=	0	C=	0				

MAIN CIRCUIT BREAKER FRAME 100 AMPERES - CALIB 70 AMPERES

MINIMUM AIC RATING = 30,000 AMPERES SYMMETRICAL

TOTAL CONNECTED LOAD 0.0 KVA

PANEL SCHEDULE '3D-E2'

MANUFACTURER: GENERAL ELECTRIC SERIES 'A' (EXISTING)

120 / 208 VOLTS - 3 PHASE - 4 WIRE - SURFACE MOUNTED

CIR	FOR	BREAKER POLE	BREAKER TRIP	AMPERES/PHASE A		AMPERES/PHASE B		AMPERES/PHASE C		CIR	FOR	BREAKER POLE	BREAKER TRIP
1	SERVICE BAY	1	20	0.0	0.0	-	-	-	-	2	LABORATORY	1	20
3	LAB	1	20	-	-	0.0	0.0	-	-	4	MEDICAL RECORDS	1	20
5	LAB	1	20	-	-	-	-	0.0	0.0	6	ELECTRIC RM	1	20
7	HOOD	1	20	0.0	0.0	-	-	-	-	8	SIGNAL CLOSET	1	20
9	LAB	1	20	-	-	0.0	0.0	-	-	10	TELEPHONE CLOSET	1	20
11	HOOD	1	20	-	-	-	-	0.0	0.0	12	SPARE	-	-
13	LAB	1	20	0.0	0.0	-	-	-	-	14	3D-119A TWIST-LOCK	2	30
15	LAB	1	20	-	-	0.0	0.0	-	-	16	----------	-	-
17	LAB	1	20	-	-	-	-	0.0	0.0	18	3D-119A TWIST-LOCK	2	30
19	SPACE	1	-	0.0	0.0	-	-	-	-	20	----------	-	-
21	SPACE	1	-	-	-	0.0	0.0	-	-	22	JTC	1	20
23	SPACE	1	-	-	-	-	-	0.0	0.0	24	SPACE	1	-
25	SPACE	1	-	0.0	0.0	-	-	-	-	26	SPACE	1	-
27	SPACE	1	-	-	-	0.0	0.0	-	-	28	SPACE	1	-
29	SPACE	1	-	-	-	-	-	0.0	0.0	30	SPACE	1	-
31	SPACE	1	-	0.0	0.0	-	-	-	-	32	SPACE	1	-
33	SPACE	1	-	-	-	0.0	0.0	-	-	34	SPACE	1	-
35	SPACE	1	-	-	-	-	-	0.0	0.0	36	SPACE	1	-
37	SPACE	1	-	0.0	0.0	-	-	-	-	38	SPACE	1	-
39	SPACE	1	-	-	-	0.0	0.0	-	-	40	SPACE	1	-
41	SPACE	1	-	-	-	-	-	0.0	0.0	42	SPACE	1	-
				0	0	0	0	0	0				
			TOTALS	A=	0	B=	0	C=	0				

MAIN LUGS ONLY 125 AMPERES

MINIMUM AIC RATING = 22,000 AMPERES SYMMETRICAL

TOTAL CONNECTED LOAD 0.0 KVA

GENERAL NOTES: (APPLIES TO THIS SHEET ONLY)

1. THE PANEL SCHEDULES SHOWN REPRESENT THE EXISTING CONDITIONS. THE CONTRACTOR SHALL BE RESPONSIBLE TO IDENTIFY THE EXISTING CIRCUIT BREAKERS THAT BECOME AVAILABLE AS A RESULT OF DEMOLITION. REUSE THESE NEWLY AVAILABLE CIRCUIT BREAKERS AND EXISTING SPARE CIRCUIT BREAKERS FOR THE NEW LOADS INDICATED ON THE FLOOR PLANS. REVISE AND PROVIDE A NEW TYPED PANEL DIRECTORY TO REPRESENT THE NEW AS-BUILT CONDITIONS PER THIS DESIGN. PROVIDE NEW CIRCUIT BREAKERS AS REQUIRED WHERE SPARE CIRCUIT BREAKERS ARE NOT AVAILABLE.

FULLY SPRINKLERED

100% SUBMISSION

Revisions: Date

CONSULTANTS:

ARCHITECT/ENGINEERS:

MIMAR ARCHITECTS, INC.
Architecture, Engineering, Design/Build
7000 Security Blvd, Suite #320
Baltimore, MD 21244
Phone: 410-944-4900 Fax: 410-499-8044

EBL ENGINEERS, LLC
MECHANICAL · ELECTRICAL · FIRE PROTECTION
The Professional Engineering Center
8005 Harford Road, Baltimore, Maryland 21234-5701
(410) 668-8000 FAX (410) 668-8001
e-mail ebl@eblengineers.com

Drawing Title: ELECTRICAL PANEL SCHEDULES - THIRD FLOOR

Approved: Project Director
APPROVED - BY - NAME
APPROVED - BY - TITLE/RANK
STATION - MANAGEMENT

Project Title: RENOVATE / BACKFILL ONCOLOGY 2C, 3D SLEEP LAB AND MSO

Location: VAMC BALTIMORE, MD.

Date: OCTOBER 1, 2014 | Checked: RJH | Drawn: JEM

Project Number: 512-14-102

Building Number: -

Drawing Number: EI-602

Dwg. 97 of 98

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231

G:\projects\2014\14901.001\cadd\submission 100%\14901.001 EI-602.dwg 9-30-14 01:36:48 PM jmcginis

PANEL SCHEDULE '6B-E2' (CRITICAL)

MANUFACTURER: GENERAL ELECTRIC SERIES 'A' (EXISTING)

120 / 208 VOLTS - 3 PHASE - 4 WIRE - SURFACE MOUNTED

CIR	FOR	BREAKER POLE	BREAKER TRIP	AMPERES/PHASE A		AMPERES/PHASE B		AMPERES/PHASE C		CIR	FOR	BREAKER POLE	BREAKER TRIP
1	BEDROOMS	1	20	0.0	0.0	-	-	-	-	2	NEW F/A FACP	1	20
3	BEDROOMS	1	20	-	-	0.0	0.0	-	-	4	SECLUSION TOILET	1	20
5	SPARE	1	20	-	-	-	-	0.0	0.0	6	BEDROOMS	1	30
7	NOURISHMENT-REFRIDGE	1	20	0.0	0.0	-	-	-	-	8	BEDROOMS	1	20
9	PATIENT ROOM	1	20	-	-	0.0	0.0	-	-	10	SPARE	1	20
11	PATIENT ROOM	1	20	-	-	-	-	0.0	0.0	12	PATIENT ROOMS	1	20
13	PATIENT ROOM	1	20	0.0	0.0	-	-	-	-	14	PATIENT ROOMS	1	20
15	6B-139 COUNTER	1	20	-	-	0.0	0.0	-	-	16	PATIENT ROOMS	1	20
17	SECLUSION	1	20	-	-	-	-	0.0	0.0	18	ELECTRCAL ROOM	1	20
19	M/E/C	1	20	0.0	0.0	-	-	-	-	20	FA CLOSET	1	20
21	P.T. TRANSFER ST.	1	20	-	-	0.0	0.0	-	-	22	TTB-6B	1	20
23	SPARE	1	20	-	-	-	-	0.0	0.0	24	NCEC-6B	1	20
25	6B-129B 30A TWIST LOCK (LEFT)	2	30	0.0	0.0	-	-	-	-	26	ICE MACHINE	1	20
27	----------	-	-	-	-	0.0	0.0	-	-	28	SPARE	1	20
29	6B-129B 30A TWIST LOCK (RIGHT)	2	30	-	-	-	-	0.0	0.0	30	SPACE	-	-
31	----------	-	-	0.0	0.0	-	-	-	-	32	SPACE	-	-
33	SPACE	-	-	-	-	0.0	0.0	-	-	34	SPACE	-	-
35	SPACE	-	-	-	-	-	-	0.0	0.0	36	SPACE	-	-
37	SPACE	-	-	0.0	0.0	-	-	-	-	38	PANELS '4B-E2' & '5B-E2'	3	100
39	SPACE	-	-	-	-	0.0	0.0	-	-	40	----------	-	-
41	SPACE	-	-	-	-	-	-	0.0	0.0	42	----------	-	-
				0	0	0	0	0	0				
			TOTALS	A=	0	B=	0	C=	0				

MAIN CIRCUIT BREAKER FRAME 225 AMPERES - CALIB 175 AMPERES

MINIMUM AIC RATING = 22,000 AMPERES SYMMETRICAL

TOTAL CONNECTED LOAD 0.0 KVA

PANEL SCHEDULE '6B-H'

MANUFACTURER: GENERAL ELECTRIC SERIES 'CCB' (EXISTING)

277 / 480 VOLTS - 3 PHASE - 4 WIRE - SURFACE MOUNTED

CIR	FOR	BREAKER POLE	BREAKER TRIP	AMPERES/PHASE A		AMPERES/PHASE B		AMPERES/PHASE C		CIR	FOR	BREAKER POLE	BREAKER TRIP
8	PANEL '6AB-H'	3		0.0	0.0	-	-	-	-	14		-	-
10	----------	-	-	-	-	0.0	0.0	-	-	16		-	-
12	----------	-	-	-	-	-	-	0.0	0.0	18		-	-
1	OFFICES	1	20	0.0	0.0	-	-	-	-	2	CORRIDOR	1	20
3	OFFICES	1	20	-	-	0.0	0.0	-	-	4	PATIENT ROOMS	1	20
5	CORRIDOR	1	20	-	-	-	-	0.0	0.0	6	PATIENT ROOMS	1	20
7	E/E/C	1	20	0.0	0.0	-	-	-	-	8	SPACE	-	-
9	SPARE	1	20	-	-	0.0	0.0	-	-	10	SPACE	-	-
11	SPACE	-	-	-	-	-	-	0.0	0.0	12	SPACE	-	-
13	SPACE	-	-	0.0	0.0	-	-	-	-	14	CONTROL RELAYS LTG	1	20
15	SPACE	-	-	-	-	0.0	0.0	-	-	16	INTERST LIGHTS	1	20
17	SPACE	-	-	-	-	-	-	0.0	0.0	18	INTERST LIGHTS	1	20
19	SPACE	-	-	0.0	0.0	-	-	-	-	20	INTERST LIGHTS	1	20
21	SPACE	-	-	-	-	0.0	0.0	-	-	22	SPACE	-	-
23	SPACE	-	-	-	-	-	-	0.0	0.0	24	SPACE	-	-
25	SPACE	-	-	0.0	0.0	-	-	-	-	26	SPACE	-	-
27	SPACE	-	-	-	-	0.0	0.0	-	-	28	SPACE	-	-
29	SPACE	-	-	-	-	-	-	0.0	0.0	30	SPACE	-	-
31	SPACE	-	-	0.0	0.0	-	-	-	-	32	SPACE	-	-
33	SPACE	-	-	-	-	0.0	0.0	-	-	34	SPACE	-	-
35	SPACE	-	-	-	-	-	-	0.0	0.0	36	SPACE	-	-
				0	0	0	0	0	0				
			TOTALS	A=	0	B=	0	C=	0				

MAIN LUGS ONLY 225 AMPERES

MINIMUM AIC RATING = 30,000 AMPERES SYMMETRICAL

TOTAL CONNECTED LOAD 0.0 KVA

GENERAL NOTES: (APPLIES TO THIS SHEET ONLY)

1. THE PANEL SCHEDULES SHOWN REPRESENT THE EXISTING CONDITIONS. THE CONTRACTOR SHALL BE RESPONSIBLE TO IDENTIFY THE EXISTING CIRCUIT BREAKERS THAT BECOME AVAILABLE AS A RESULT OF DEMOLITION. REUSE THESE NEWLY AVAILABLE CIRCUIT BREAKERS AND EXISTING SPARE CIRCUIT BREAKERS FOR THE NEW LOADS INDICATED ON THE FLOOR PLANS. REVISE AND PROVIDE A NEW TYPED PANEL DIRECTORY TO REPRESENT THE NEW AS-BUILT CONDITIONS PER THIS DESIGN. PROVIDE NEW CIRCUIT BREAKERS AS REQUIRED WHERE SPARE CIRCUIT BREAKERS ARE NOT AVAILABLE.

PANEL SCHEDULE '6B-L' (SECTION 1)

MANUFACTURER: GENERAL ELECTRIC SERIES 'A' (EXISTING)

120 / 208 VOLTS - 3 PHASE - 4 WIRE - SURFACE MOUNTED

CIR	FOR	BREAKER POLE	BREAKER TRIP	AMPERES/PHASE A		AMPERES/PHASE B		AMPERES/PHASE C		CIR	FOR	BREAKER POLE	BREAKER TRIP
1	BATHROOMS	1	20	0.0	0.0	-	-	-	-	2	BATHROOMS	1	20
3	OFFICE	1	20	-	-	0.0	0.0	-	-	4	OFFICE	1	20
5	OFFICE	1	20	-	-	-	-	0.0	0.0	6	OFFICE	1	30
7	OFFICE	1	20	0.0	0.0	-	-	-	-	8	OFFICE	1	20
9	OFFICE	1	20	-	-	0.0	0.0	-	-	10	OFFICE	1	20
11	OFFICE	1	20	-	-	-	-	0.0	0.0	12	OFFICE	1	20
13	OFFICE	1	20	0.0	0.0	-	-	-	-	14	OFFICE	1	20
15	OFFICE	1	20	-	-	0.0	0.0	-	-	16	BATHROOMS	1	20
17	PATIENT ROOM	1	20	-	-	-	-	0.0	0.0	18	LAUNDRY	1	20
19	PATIENT ROOM	1	20	0.0	0.0	-	-	-	-	20	BATHROOMS	1	20
21	PATIENT ROOM	1	20	-	-	0.0	0.0	-	-	22	BATHROOMS	1	20
23	PATIENT ROOM	1	20	-	-	-	-	0.0	0.0	24	HOUSE STAFF	1	20
25	PATIENT ROOM	1	20	0.0	0.0	-	-	-	-	26	BATHROOMS	1	20
27	PATIENT ROOM	1	20	-	-	0.0	0.0	-	-	28	PATIENT ROOM	1	20
29	ROBOT CIRCUIT	1	20	-	-	-	-	0.0	0.0	30	PATIENT ROOM	1	20
31	PATIENT ROOM	1	20	0.0	0.0	-	-	-	-	32	PATIENT ROOM	1	20
33	QUITE	1	20	-	-	0.0	0.0	-	-	34	PATIENT ROOM	1	20
35	EXERCISE	1	20	-	-	-	-	0.0	0.0	36	PATIENT ROOM	1	20
37	EXAM	1	20	0.0	0.0	-	-	-	-	38	PATIENT ROOM	1	20
39	TUB	1	20	-	-	0.0	0.0	-	-	40	HAC, STAIR	1	20
41	BATHROOMS	1	20	-	-	-	-	0.0	0.0	42	CORRIDOR	1	20
				0	0	0	0	0	0				
			TOTALS	A=	0	B=	0	C=	0				

MAIN CIRCUIT BREAKER FRAME 400 AMPERES - CALIB 400 AMPERES

MINIMUM AIC RATING = 22,000 AMPERES SYMMETRICAL

TOTAL CONNECTED LOAD 0.0 KVA

PANEL SCHEDULE '6B-L' (SECTION 2)

MANUFACTURER: GENERAL ELECTRIC SERIES 'A' (EXISTING)

120 / 208 VOLTS - 3 PHASE - 4 WIRE - SURFACE MOUNTED

CIR	FOR	BREAKER POLE	BREAKER TRIP	AMPERES/PHASE A		AMPERES/PHASE B		AMPERES/PHASE C		CIR	FOR	BREAKER POLE	BREAKER TRIP
		-	-	0.0	0.0	-	-	-	-			-	-
		-	-	-	-	0.0	0.0	-	-			-	-
		-	-	-	-	-	-	0.0	0.0			-	-
43	LINEN, CLEAN UTIL	1	20	0.0	0.0	-	-	-	-	44	DWC	1	20
45	COORIDOR	1	20	-	-	0.0	0.0	-	-	46	SERVICE BAY	1	20
47	DWC	1	20	-	-	-	-	0.0	0.0	48	RECEPT - 7TH LR CATWALK	1	20
49	UHS #47, 70671	1	15	0.0	0.0	-	-	-	-	50	JUNCTION BOX	1	20
51	UHS #67, 68 ,69	1	15	-	-	0.0	0.0	-	-	52	SPARE	1	20
53	PH MECH ROOM	1	15	-	-	-	-	0.0	0.0	54	UH #43	1	15
55	PH MECH ROOM	1	20	0.0	0.0	-	-	-	-	56	PANEL '6 AB-L'	-	-
57	UH #55	1	15	-	-	0.0	0.0	-	-	58	PANEL '6 AB-L'	-	-
59	UH #53	1	15	-	-	-	-	0.0	0.0	60	PANEL '6 AB-L'	-	-
61	UH #54	1	15	0.0	0.0	-	-	-	-	62	LIGHTS ON AC #28	1	20
63	PATIENT ROOMS	1	20	-	-	0.0	0.0	-	-	64	PATIENT ROOMS	1	20
65	PATIENT ROOMS	1	20	-	-	-	-	0.0	0.0	66	PATIENT ROOMS	1	20
67	PATIENT ROOMS	1	20	0.0	0.0	-	-	-	-	68	PATIENT ROOMS	1	20
69	ATRIUM LIGHTING 7B	2	50	-	-	0.0	0.0	-	-	70	DRYER	2	30
71	----------	-	-	-	-	-	-	0.0	0.0	72	----------	-	-
73	SPACE	1	-	0.0	0.0	-	-	-	-	74	WASHER	1	20
75	SPACE	1	-	-	-	0.0	0.0	-	-	76	SPARE	1	20
77	SPACE	1	-	-	-	-	-	0.0	0.0	78	SPACE	-	-
				0	0	0	0	0	0				
			TOTALS	A=	0	B=	0	C=	0				

MAIN CIRCUIT BREAKER FRAME 225 AMPERES - CALIB 200 AMPERES

MINIMUM AIC RATING = 22,000 AMPERES SYMMETRICAL

TOTAL CONNECTED LOAD 0.0 KVA

Revisions:	Date

CONSULTANTS:

ARCHITECT/ENGINEERS:

MIMAR ARCHITECTS, INC.
Architecture, Engineering, Design/Build
7000 Security Blvd, Suite #320
Baltimore, MD 21244
Phone: 410-944-4900 Fax: 410-499-8044

EBL ENGINEERS, LLC
MECHANICAL • ELECTRICAL • FIRE PROTECTION
The Professional Engineering Center
8005 Harford Road, Baltimore, Maryland 21234-5701
(410) 668-8000 FAX (410) 668-8001
e-mail ebl@eblengineers.com

Drawing Title: ELECTRICAL PANEL SCHEDULES - SIXTH FLOOR

Approved Project Director: APPROVED - BY - NAME; APPROVED - BY - TITLE/RANK; STATION - MANAGEMENT

FULLY SPRINKLERED

Project Title: RENOVATE / BACKFILL ONCOLOGY 2C, 3D SLEEP LAB AND MSO

Location: VAMC BALTIMORE, MD.

Date: OCTOBER 1, 2014 | Checked: RJH | Drawn: JEM

100% SUBMISSION

Project Number: 512-14-102

Building Number: -

Drawing Number: EI-603

Dwg. 98 of 98

Office of Construction and Facilities Management

Department of Veterans Affairs

VA FORM 08-6231

G:\projects\2014\14901.001\cadd\submission 100%\14901.001 EI-603.dwg 9-30-14 01:36:28 PM jmcginnis