

DOCUMENT 00 04 93
ADDENDUM NO. 3

DATE: March 10, 2015

PROJECT NAME: Renovate & Expand Space for Patient Support Areas

This Addendum forms a part of the bidding and contract documents. This Addendum supersedes and supplements all portions of the original bidding and contract documents dated December 5, 2014 with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

A. DRAWINGS

1. SHEET 2-S3 - SECOND FLOOR FRAMING PLAN
 - a. **ADD** General Plan Note #7 as follows:

"7. USE THE FOLLOWING LINTELS OVER OPENINGS THROUGH
INTERIOR NON LOAD-BEARING MASONRY:
A. 8" DEEP BOND BEAM W/ (2)#5 BARS FOR OPENINGS LESS
THAN 6'-0" WIDE
B. 16" DEEP BOND BEAM W/ (2)#5 BARS FOR OPENINGS 6'-0"
TO 8'-6" WIDE
C. PROVIDE SOLID GROUTED JAMBS AND MINIMUM 8" OF BEARING
UNDER LINTELS AT EACH SIDE OF OPENINGS"
2. SHEET 2-S4 - ROOF FRAMING PLAN
 - a. **ADD** BB-1 and L3x3x3/8 galvanized loose lintel over door on Grid D between Grids 2 and 3 and on Grid 6 between Grids G and H. Refer to architectural drawing for location of doors.
 - b. **ADD** section cut 7/2-S7 at windows on Grid D between Grids 3 and 6.
3. SHEET 2-S12 - STRUCTURAL BEAM DETAILS
 - a. On detail 4, **REVISE** depth of concrete beam and reinforcement for beam "3B5" between Grids 3 and 6 to match beam "3B1" between Grids 3 and 4. Width of beam "3B5" to remain 20 inches.
4. SHEET 2-A2 - CONSTRUCTION PLAN - SECOND FLOOR
 - a. Reference SECOND FLOOR CONSTRUCTION PLAN, door No. 2C01: **ADD** dimension string from grid line G to centerline of door. Dimension shall be 3'-5".

DOCUMENT 00 04 93
ADDENDUM NO. 3

5. SHEET 2-A23 - EGRESS STAIR SECTIONS AND PLANS
 - a. Reference Enlarged Plan 8, ENLARGED EGRESS STAIR PLAN @ LEVEL 2, door No. 2ST02.2: **REVISE** door to be moved to the EAST 0'-5". Centerline of door from grid line 3 shall be 3'-5".
6. SHEET 2-A29 - DETAILS
 - a. Reference Detail 4, CURTAINWALL/STOREFRONT HEAD AT BRICK: Detail 4, "CURTAINWALL/STOREFRONT HEAD AT BRICK" **REVISE** title to read as follows: "STOREFRONT HEAD AT BRICK OPENING".

Prepared By: Shive-Hattery, Inc.

Doyle Harper, AIA, LEED AP,
Iowa License No.
My registration renewal date is

END OF DOCUMENT 00 04 93