

March 19, 2015

**Renovate 13B for Acute Care and Intensive Care Unit
Carl Vinson VA Medical Center, Dublin, Georgia
VA Project No. 557-14-105**

The following items are incorporated into the project Construction Documents by Addendum:

Drawing Items:

1. Sheet A-1.0R is modified and re-issued by this Addendum. Replace and void prior sheet.
2. Sheet A-1.1R is modified and re-issued by this Addendum. Replace and void prior sheet.
3. Sheet A-1.4R is modified and re-issued by this Addendum. Replace and void prior sheet.
4. Sheet A-2.0R is modified and re-issued by this Addendum. Replace and void prior sheet.
5. Sheet A-2.1R is modified and re-issued by this Addendum. Replace and void prior sheet.
6. Sheet A-3.0R is modified and re-issued by this Addendum. Replace and void prior sheet.
7. Sheet A-6.1R is modified and re-issued by this Addendum. Replace and void prior sheet.
8. Sheet A-7.0R, Keyed Note 3, add "and Patient Bath rooms and Toilet rooms."
9. Sheet F-0.1, add the following to the Fire Protection General Notes: "16. Sprinkler heads shall be located to be centered on ceiling tiles and, where located on gypsum board ceilings, soffits, or fascias, centered and aligned on those surfaces."
10. Sheet P-1.2 is modified and re-issued by this Addendum. Replace and void prior sheet.
11. Sheet P-2.1 is modified and re-issued by this Addendum. Replace and void prior sheet.

Specification Items:

12. Section 00 01 10 TABLE OF CONTENTS, page 1, below Section 01 81 11, add Section number 01 91 00 Commissioning, with VA Rev Date of 06-13.
13. Section 00 01 15 List of Drawing Sheets, page 1, add to the ARCHITECTURAL list below A-6.1 and above A-7.1 the following:
"A-7.0 Second Floor Plan – Flooring Layout"
14. Section 01 91 00 is issued by this Addendum.
15. Section 10 14 00 is issued by this Addendum.

End