



LEGEND

- 102 D-03600 Three Unit Draft Gauge
Windbox Pressure 0 to 6.0 " W.C.
Furnace Draft Pressure -0.5 to +1.0"W.C.
Boiler Outlet Pressure -0.5 to +1.0"W.C.
- 103 D-02100 Circular Chart Recorder with Steam Flow Integrator
Blr Stm Flow 0 - 40,000 lbs/hr (press. compensated)
Flue Gas Temp. 0 - 800 Deg. F
Oxygen 0 - 10%
- 104 D-02100 Circular Chart Recorder
Drum Level
- 105 C-10004 CCP
E16 Sub-master M/A Station
E06 Jackshaft M/A Station
- 107 E01 Feedwater Master M/A Station
E06 Feedwater Valve M/A Station
E30 Air Trim Manual Station
- 108 High Water & Low Water Alarm Lights
- 110 Elapsed Time, Running Hour Meter
- 111 C-10004 CCP A01, Controller Card Cage
- 112 Burner Control by Coen
- 113 Alarm Bell
- 118 Alarm Horn with Test & Acknowledge Pushbuttons
- 119 A-10018 Oxygen Analyzer Electronics
- 120

Panel - 86" X 51" X 24" with lighted canopy, painted black, Textured exterior and white interior.

DIMENSIONS IN MILLIMETERS / INCHES	DR. JVA	Hays Republic Division of Teikokai Inc.	
	DATE	V.A. PALO ALTO	
DO NOT SCALE DRAWING	CH.	BOILER PANEL ARRANGEMENT	
	R & D		
CONFIDENTIAL INFORMATION NOT TO BE COPIED OR USED WITHOUT WRITTEN CONSENT OF HAYS REPUBLIC	MF.	SCALE	REV.
	FINISH	SHEET 1 OF 1	DWG. NO. B66863