





AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF PAGES 2
2. AMENDMENT/MODIFICATION NO. A00005		3. EFFECTIVE DATE 04-08-2015		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY Department of Veterans Affairs NCA Contracting Service 75 Barrett Heights Rd. Suite 309 Stafford VA 22556		CODE 43C1	7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs NCA Contracting Service 75 Barrett Heights Rd. Suite 309 Stafford VA 22556		CODE 43C1	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) To all Offerors/Bidders			(X)	9A. AMENDMENT OF SOLICITATION NO. VA786-15-Q-0103		
				9B. DATED (SEE ITEM 11) 04-08-2015		
			X	10A. MODIFICATION OF CONTRACT/ORDER NO.		
				10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).					
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
	D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) SOLICITATION AMENDMENT ISSUED TO: 1. ADD ATTACHMENT A, REVISED DIAGRAM OF MAINTENANCE BUILDING.						
OFFERORS ARE REQUIRED TO SUBMIT REVISED TECHNICAL PROPOSALS AND REVISED PRICE SCHEDULES, VIA EMAIL, TO KENNETH DOUGHERTY NO LATER THAN 1200 PM ET ON 4/9/2015.						
THE REQUESTED REVISIONS WILL ONLY BE ACCEPTED BY THOSE OFFERORS WHOM SUBMITTED THEIR ORIGINAL PROPOSALS BY THE ORIGINALLY PRESCRIBED DEADLINE.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) KENNETH DOUGHERTY CONTRACTING OFFICER			
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY  (Signature of Contracting Officer)		16C. DATE SIGNED 4/8/2015	

TYPE	QTY	SIZE	WATTS	LUMENS	TEMP (K)	FIXTURE
A	19	48"	80	7,752	5000K	LED COMMERCIAL STRIP, SUSPENDED (1)
B	6*	48"	40	3,876	5000K	LED COMMERCIAL STRIP, SUSPENDED (1)
BB	4	48"	40	3,876	5000K	LED COMMERCIAL STRIP WALL MOUNT (1)
C	4	24"	30	3,017	5000K	LED UTILITY WRAP WALL MOUNT (2)

(1) (ILP OR EQUAL)W/ OPTIONAL HOUSING & FROSTED LENS KITS.
(2) (MAXLITE OR EQUAL) SEE, <http://www.prolighting.com>
* 4 FIXTURES ARE IN PUBLIC RESTROOM, NOT SHOWN.

REPLACE EXIXTING SUSPENDED AND WALL MOUNTED
FLUORESCENT FIXTURES IN ACCORDACNE WITH SCHEDULE.
ATTACH SAFETY TETHER/CHAIN ON SUSPENDED FIXTURES.

-  HARDWIRED HYDRONIC BASEBOARD ELECTRIC HEATER WITH BUILT-IN THERMOSTAT
-  EXISTING WALL MOUNTED FLUORESCENT FIXTURE
-  2X4 OR 1X4 EXISTING SUSPENDED FLUORESCENT FIXTURES TO BE REPLACED

