



LEGEND	
	FIRE EXTINGUISHER
	FIRE ALARM PULL STATION
	AUDIO VISUAL DEVICE
E	DENOTES EXISTING

CODES
APPLICABLE CODES (LATEST EDITIONS): INTERNATIONAL FIRE CODE ADA AND ABA ACCESSIBILITY GUIDELINES NFPA 101 LIFE SAFETY CODE NFPA 72 NATIONAL FIRE ALARM AND SIGNALING CODE

- FIRE ALARM NOTES**
- ALL WORK SHALL BE IN ACCORDANCE WITH THE VA FIRE PROTECTION DESIGN GUIDE AND NFPA 72.
  - EXTEND THE EXISTING FIRE ALARM SYSTEM WHICH COVERS BUILDINGS 190 AND 191 INTO THE NEW BUILDING 195. PROVIDE DEVICES AS SHOWN.
  - CIRCUITS SHALL BE CLASS B.
  - THE EXISTING FACP IS LOCATED JUST OUTSIDE ROOM 216 ON THE SECOND FLOOR OF BUILDING 190. PROGRAM THE EXISTING SYSTEM FOR THE NEW DEVICES.
  - ALL NEW FIRE ALARM DEVICES AND EQUIPMENT SHALL BE EDWARDS EST TO MATCH EXISTING.
  - EXISTING FIRE ALARM SYSTEM OUTAGES SHALL BE KEPT TO A MINIMUM AND COORDINATED WITH THE COR 48 HOURS IN ADVANCE OF ANY OUTAGE. THE SYSTEM SHALL BE PLACED IN SERVICE AT THE END OF EACH WORK DAY OR THE CONTRACTOR SHALL PROVIDE A ROVING FIRE WATCH 24 HRS A DAY UNTIL THE OUTAGE IS COMPLETE.
  - THE CONTRACTOR IS RESPONSIBLE FOR VERIFYING THE LOCATION OF ANY EXISTING DEVICES SHOWN.
  - NO FIRE ALARM DEVICES ARE TO BE LOCATED DOWN RANGE OF THE SHOOTERS FIRING STATIONS WITHIN THE FIRING RANGE.

**1 LIFE SAFETY PLAN**  
1/8"=1'-0"



**CONSTRUCTION DOCUMENTS  
UNSPRINKLERED**

Revisions:	Date

**CONSULTANTS:**



**ARCHITECT/ENGINEERS:**

BES DESIGN/BUILD, LLC  
766 Middle St, Fairhope, AL 36532  
Phone: 251.990.5778  
Fax: 251.990.3716

Drawing Title <b>FIRE PROTECTION PLAN</b>
Approved: Project Director

Project Title <b>LETC FIRING RANGE SITE ADAPTATION</b>	Project Number 598-12-207
Location <b>NORTH LITTLE ROCK, ARKANSAS</b>	Building Number 195
Date 10-10-2014	Checked <b>MADDY</b>
Drawn <b>MADDY</b>	Drawing Number <b>FP001</b>
Dwg. 58 of 58	

**CENTRAL ARKANSAS  
VETERANS AFFAIRS  
HEALTHCARE  
SYSTEM**