

three inches = one foot

one and one half inches = one foot

one inch = one foot

three quarters inch = one foot

one half inch = one foot

one quarter inch = one foot

one eighth inch = one foot

one eighth inch = one foot

GENERAL NOTES:

1. AREAS INDICATING "SRADP" SHALL HAVE SECURE RADIANT PANELS INSTALLED WITH TAMPER PROOF SCREWS.

KEYNOTES:

- 1 80 SSDCP-4 130 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 2 10x10 SRDCP 130 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 3 BALANCE VVB-4B12 FROM 220 CFM TO 130 CFM
- 4 160 SSDCP-4 600 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 5 16x16 SRDCP 600 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 6 PROVIDE CAP ON DUCTWORK WHERE INDICATED
- 7 BALANCE 80 SSDCP-2 FROM 200 CFM TO 130 CFM
- 8 60 SSDCP-2 70 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 9 NEW LOCATION OF EXISTING 8x8 SRDCP SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS BALANCE TO 200 CFM
- 10 NEW LOCATION OF EXISTING 80 SSDCP-4 SECURE DIFFUSER TO CEILING GRID WITH TAMPER PROOF SCREWS BALANCE TO 145 CFM
- 11 NEW LOCATION OF EXISTING 60 SSDCP-4 SECURE DIFFUSER TO CEILING GRID WITH TAMPER PROOF SCREWS BALANCE TO 80 CFM
- 12 12x12 SRDCP 275 CFM
- 13 100 SSDCP-4 275 CFM
- 14 NEW LOCATION OF EXISTING VVB-4B25 INCLUDING ALL ITS ASSOCIATED CONTROLS & ACCESSORIES. PROVIDE DUCTWORK AS REQUIRED SAME SIZE AS EXISTING TO SUPPORT NEW LOCATION OF VVB.
- 15 PROVIDE DUCTWORK AS REQUIRED SAME SIZE AS EXISTING.
- 16 NEW LOCATION OF EXISTING 10x10 SERC SECURE REGISTER TO CEILING GRID WITH TAMPER PROOF SCREWS BALANCE TO 150 CFM
- 17 8x8 SERC, 100 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 18 14x14 SRDCP 450 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 19 100 SSDCP-4, 225 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 20 12x12 SRDCP 300 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 21 100 SSDCP-4, 300 CFM SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS
- 22 100 SSDCP-4, CFM TO BE DETERMINED BASED ON PRE-DEMOLITION MEASUREMENT. SECURE GRILLE TO CEILING GRID WITH TAMPER PROOF SCREWS

7" - 48" LINEAR SLOT DIFFUSER

EX 22x30 UP, 30x30 DN (AH-23)

EX 200 UP, 240 DN

EXISTING ELECTRICAL ROOM (4B41)

EXISTING STAIR (4B43)

EXISTING ELEVATOR LOBBY (4B47)

EXISTING MECHANICAL (4B48)

1 PARTIAL FOURTH FLOOR PLAN - DUCTWORK

Scale: 1/8" = 1'-0"

0 4 8 16

Project North True North

CONSULTANTS:



H.F. LENZ COMPANY

1407 Scalp Avenue Johnstown, PA 15904
Phone: 814-269-9300 FAX: 814-269-9301
cadd@hflenzen.com www.hflenzen.com
Engineers • Planners • Surveyors • Energy Consultants

ARCHITECT/ENGINEERS:



architecture
planning
interior design
IKM Incorporated
One PPG Place
Pittsburgh, PA 15222
412-281-1337
www.ikmnc.com

Drawing Title

PARTIAL FOURTH FLOOR
PLAN - DUCTWORK

Approved: Project Director

Project Title
Clarksburg VAMC Fourth Floor B
Acute Inpatient Mental Health
Lock Down Conversion

Location
VAMC Clarksburg West Virginia

Date
March 13, 2015

Checked
TME

Drawn
NJB

VA Project Number
540-11-106
IKM Project Number
11-024.1

Building Number

Drawing Number

M201

Dwg. X of X

Office of
Construction
and Facilities
Management

