


PARTITION TYPE - ZPARTITION TYPE - DPARTITION TYPE - CPARTITION TYPE - BPARTITION TYPE - A

PARTITION TAG NOTES: 

PARTITION TAGS ARE READ LEFT TO RIGHT:

- EXAMPLE:
A TAG OF C3T INDICATES A 4- $\frac{7}{8}$ " 1 HOUR RATED BARRIER WITH ACOUSTICAL INSULATION.

PARTITION TYPE - C

F6 PARTITION TYPES

SCALE: 1" = 1'-0"

0 3" 6" 1' 2'

1. ERECT PARTITIONS IN ORDER OF RATING PRIORITY BEGINNING WITH HIGHEST RATED PARTITION. CONSTRUCTION OF HIGHER RATED PARTITIONS SHALL BE CONTINUOUS PAST/THROUGH LOWER RATED INTERSECTING PARTITION.
2. ALL STUD GAUGES AND LIMITING HEIGHTS IN GYPSUM BOARD REFERENCE SPECIFICATIONS.
3. REFER TO PLANS FOR LOCATION OF PARTITION TYPES. C3 IS THE TYPICAL PARTITION TYPE UON.
4. ALL PARTITIONS CONTAINING PLUMBING OR HAVING AN EXTERIOR FACE TO BE INSULATED.
5. THE FOLLOWING LIST OF ROOMS (IF USED) SHALL HAVE THEIR PERIMETER PARTITIONS INSULATED USING MINERAL WOOL:
 - ALL ELECT./MECH. ROOMS
 - A/V EQUIPMENT/LIGHTING ROOMS
6. THE FOLLOWING LIST OF ROOMS (IF USED) SHALL HAVE THEIR PERIMETER PARTITIONS INSULATED WITH SOUND ATTENUATION BATTS AS SPECIFIED.
 - TOILETS AND BATHING ROOMS
 - OFFICES
 - PATIENT ROOMS
7. ALL PATIENT ISOLATION ROOMS SHALL HAVE THEIR PERIMETER PARTITIONS CONSTRUCTED AS SMOKE RESISTANT PARTITIONS (TYPE C3C) UON.
8. ALL PARTITIONS SHALL EXTEND FULL HEIGHT TO UNDERSIDE OF DECK/INTERSTITIAL ABOVE.
9. ALL RATED PARTITIONS TO EXTEND FROM TOP OF SLAB TO UNDERSIDE OF STRUCTURE. SEAL ENTIRE PERIMETER WITH FIRESTOP SEALANT UON.
10. ALL INTERIOR FLOOR DRAINS AND OVERFLOW DRAINS TO BE WRAPPED CONTINUOUSLY WITH SOUND ATTENUATION INSULATION.
11. INSTALL FRAMING AND GWB TO OFFSET AROUND STRUCTURAL MEMBERS OR OTHER OBSTRUCTIONS TO MAINTAIN FIRE RESISTIVE RATINGS.
12. WHERE GWB EXTENDS TO THE UNDERSIDE OF STRUCTURE, STOP GWB 1/2" BELOW LINE OF STRUCTURE AND SEAL AS REQUIRED.
13. NON-RATED PARTITIONS SHALL HAVE ENTIRE PERIMETER SEAL WITH ACOUSTICAL SEALANT UON.
14. REFER TO MECHANICAL DRAWINGS FOR DETAILS ON PIPE PENETRATIONS THROUGH ACOUSTICAL PARTITIONS AS WELL AS RATED PARTITIONS.
15. INSTALL METAL STUD BLOCKING IN PARTITIONS AT ALL WALL MOUNTED EQUIPMENT, WHETHER C, VC OR VV.
16. ALL PARTITIONS SCHEDULED TO RECEIVE TILE, IN BATHING ROOMS AND/OR LOCATED ADJACENT TO OR BEHIND PLUMBING FIXTURES SHALL BE CONSTRUCTED OF WATER-RESISTANT CORE GWB.
17. FOR MOLD PREVENTION, DO NOT INSTALL GWB IN DIRECT CONTACT WITH THE FLOOR. ALL GWB SHALL BE SHIMMED 1/2" OF THE FLOOR WITH NON-POROUS PLASTIC NON-POROUS HORSESHOE SHIMS ARE RECOMMENDED. GWB SHIMS ARE NOT ACCEPTABLE.
18. CABLES PENETRATING RATED PARTITIONS (WITH OR WITHOUT SLEEVES) SHALL BE SECURED ON BOTH SIDES OF THE PARTITION. METHOD OF SECURING THE CABLES SHALL BE AS NECESSARY TO PRECLUDE ANY MOVEMENT OF THE CABLE DISTURBING THE INTEGRITY OF THE PENETRATION FIRE - STOPPING ASSEMBLY. SEE SPECIFICATIONS.
19. REFER TO DRAWINGS FOR TYPICAL WALL FRAMING FOR FIRE DAMPERS IN RATED WALLS. COORDINATE EXACT FRAMING REQUIREMENTS WITH FIRE DAMPER MANUFACTURER. COORDINATE ALL PARTITION CONSTRUCTION WITH MECHANICAL PRIME CONTRACTOR PRIOR TO COMMENCING PARTITION CONSTRUCTION. GENERAL CONTRACTOR SHALL OBTAIN FROM THE MECHANICAL CONTRACTOR THE PROPER INSTALLATION INSTRUCTIONS FOR ALL FIRE AND SMOKE DAMPERS AND SHALL PROVIDE THE REQUIRED METAL FRAMING, DRYWALL, ETC., ACCORDING TO THESE INSTRUCTIONS. INSTALLATION INSTRUCTIONS TO BE SUBMITTED TO THE ARCHITECT AND OWNER FOR REVIEW.
20. CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING FIRE AND SMOKE SEALED PENETRATIONS IN CONJUNCTION WITH MECHANICAL AND APPROVED PENETRATION SEALING SYSTEM FOR THE PARTITION CONSTRUCTION / FIRE RATING AND THE PENETRATING ELEMENTS.
21. PARTITION TYPES AS NOTED BY THE SYMBOL CONTINUE BETWEEN ROOM/SPACE CORNERS OR ANY INTERSECTING PARTITION.
22. DIFFERING PARTITION TYPES SHALL ALIGN SO THAT WALL PLANES CONTINUE UNBROKEN WITHIN/ACROSS ROOMS AND/OR SPACES.

REVISION NO.	REVISION DESCRIPTION	
Revisions		Rv Date



Department of Veterans Affairs
Veterans Healthcare System of
the Ozarks
1100 North College Avenue
Fayetteville, AR 72703



SEAL

Architect/Engineer Address



• DESIGN GROUP, P.C. •

formerly HARRELL, SALTRICK & HOPPER, PC

8016 TOWER POINT DRIVE P 704.814.1322
CHARLOTTE, NC 28227 F 704.321.0833
WWW.HARRELLDG.COM
COPYRIGHT © 2014 HARRELL DESIGN GROUP, PLLC
HDG PROJECT # 14001

APPROVALS

CHIEF OF ENGINEERING

Drawing Title	WALL DETAILS
---------------	--------------

FULLY SPRINKLERED

100% FINAL CONSTRUCTION
DRAWINGS

Project Title	RENOVATE 3B CLINIC FOR STEP-DOWN, B1
---------------	--------------------------------------

	Drawn

DEB

☐ Checked

DEB

Building Number

1

	Reviewed

Reviewed
JC

Date

1/8/2015

Project Number

564-14-10

DRAWING No.

DRAWING NO. _____

AE51

100

Veterans Affairs