


three inches = one foot  
one and one half inches = one foot  
one inch = one foot  
three quarters inch = one foot  
one half inch = one foot  
three eighths inch = one foot  
one quarter inch = one foot  
one eighth inch = one foot  
one sixteenth inch = one foot



- GENERAL DRAWING NOTES:
- A. DETAIL SCHEDULE ALL WORK AREAS FOR SHUT DOWNS AND RELOCATIONS MINIMUM TWO WEEKS IN ADVANCE. SEE ARCHITECTURAL PHASING PLAN AND PROVIDE CPM SCHEDULE TO COORDINATE WITH PHASING.
- B. EXISTING FIRE SPRINKLER SYSTEM IN WORK AREAS SHALL STAY ACTIVE THROUGHOUT PROJECT. TEMPORARILY REPLACE EXISTING PENDANT WITH UPRIGHT SPRINKLER AND PIPING IN AREAS THAT HAVE CEILINGS REMOVED PER NFPA 241. SHUTDOWNS FOR WORK THE THE SYSTEM SHALL BE SCHEDULED WITH THE VA TWO WEEKS IN ADVANCE AND PROVISIONS SET IN PLACE PER NFPA 241. RESTORE SYSTEM TO SERVICE AT THE END OF EACH WORK DAY.
- C. SPRINKLERS IN STAIRWAYS TO REMAIN.

1 4TH FLOOR FIRE SPRINKLER DEMOLITION PLAN - WING B  
F1.11 SCALE: 1/8" = 1'-0"

CONSULTANTS: <b>Hyman Hayes</b> 6 WEMBLEY COURT, ALBANY, NEW YORK 12205 (518) 452-3470 1511 Route 22 - Suite C-24 Brewster, New York 10509 p: 845.278.7710 f: 845.278.7750 adelaidelc.com		<b>ENGINEERING VENTURES PC</b> 208 Flynn Avenue, Suite 2A Burlington, VT 05401 tel: 802.863.6225 • fax: 802.863.6386 85 Mechanic Street, Suite 350A, Lebanon, NH 03766 tel: 603.442.9333 • fax: 603.442.9331		 <b>ARCHITECT/ENGINEERS:</b> <b>Sigma Psi Consulting</b> Mechanical, Electrical, Plumbing Engineers, PLLC 4 Collamer Road, Malta, NY 12020 PH (518) 581-9428 FX (518) 580-9325		Drawing Title <b>4TH FLOOR FIRE SPRINKLER DEMOLITION PLAN - WING B</b> Approved Project Director 		Project Title <b>Renovate 4B for Community Living Center (CLC)</b> Stratton VA Medical Center Location <b>Albany, New York</b> Date <b>10-22-2014</b> Checked  Drawn  		Project Number <b>VA 528A8-12-890</b> Building Number <b>1</b> Drawing Number <b>F1.11</b> Dwg. 39 of 79		Office of Construction and Facilities Management 	
--	--	--	--	---	--	---	--	---	--	--	--	---	--