

GENERAL DRAWING NOTES:

A. DETAIL SCHEDULE ALL WORK AREAS FOR SHUT DOWNS AND RELOCATIONS MINIMUM TWO WEEKS IN ADVANCE. SEE ARCHITECTURAL PHASING PLAN AND PROVIDE CPM SCHEDULE TO COORDINATE WITH PHASING.

B. EXISTING FIRE SPRINKLER SYSTEM IN WORK AREAS SHALL STAY ACTIVE THROUGHOUT PROJECT. TEMPORARILY REPLACE EXISTING PENDANT WITH UPRIGHT SPRINKLER AND PIPING IN AREAS THAT HAVE CEILINGS REMOVED PER NFPA 241. SHUTDOWNS FOR WORK THE THE SYSTEM SHALL BE SCHEDULED WITH THE VA TWO WEEKS IN ADVANCE AND PROVISIONS SET IN PLACE PER NFPA 241. RESTORE SYSTEM TO SERVICE AT THE END OF EACH WORK DAY.

C. SPRINKLERS IN STAIRWAYS TO REMAIN.

OFFICE AND CLINIC ROOMS BELOW ON 3RD FLOOR A SIDE. COORDINATE WITH VA TO SCHEDULE WORK AFFECTING 3RD FLOOR DURING OFF HOURS OR POSSIBLY DURING NORMAL HOURS FOR TEMPORARY PERIODS.

AUDIOLOGY DEPARTMENT ON 5A ABOVE. COORDINATE WITH VA TO SCHEDULE NOISE PRODUCING WORK DURING OFF HOURS OR POSSIBLY DURING NORMAL HOURS FOR TEMPORARY PERIODS.

1 / F1.1 **4TH FLOOR FIRE SPRINKLER DEMOLITION PLAN – WING A**

SCALE: 1/8" = 1'-0"

FINAL DESIGN (100%)

Revisions	Date
REVISED PER COMMENTS	4/30/15
100% SUBMISSION	10/22/14

CONSULTANTS:

Hyman Hayes Associates, 6 Wembley Court, Albany, New York 12205, (518) 452-3470, (518) 452-3783 Fax — HHA Proj 12085

Engineering Ventures PC, 208 Flynn Avenue, Suite 2A, Burlington, VT 05401, tel: 802.863.6225 • fax 802.863.6306; 85 Mechanic Street, Suite 350A, Lebanon, NH 03766, tel: 603.442.9333 • fax 603.442.9333

Adelaide Environmental Health Associates, Inc., 1511 Route 22 - Suite C-24, Brewster, New York 10509, p: 845.278.7710 F: 845.278.7750, adelaidellc.com

ARCHITECT/ENGINEERS:

Sigma Psi Consulting, Mechanical, Electrical, Plumbing Engineers, PLLC
4 Collamer Road, Malta, NY 12020 PH (518) 581-9428 FX (518) 580-9325

Drawing Title	4TH FLOOR FIRE SPRINKLER DEMOLITION PLAN - WING A
Approved Project Director	
Project Title	Renovate 4A for Community Living Center (CLC) Stratton VA Medical Center
Location	Albany, New York
Date	10-22-2014
Checked	
Drawn	
Project Number	VA 528A8-12-801
Building Number	1
Drawing Number	F1.1
Dwg. 60 of 117	

Office of Construction and Facilities Management
Department of Veterans Affairs

VA FORM 08-6231