


three inches = one foot  
 one and one half inches = one foot  
 one inch = one foot  
 one half inch = one foot  
 three quarters inch = one foot  
 one quarter inch = one foot  
 one eighth inch = one foot  
 one quarter inch = one foot  
 one eighth inch = one foot  
 one quarter inch = one foot  
 one eighth inch = one foot



ZVB SHALL BE EQUAL TO BEACONMEDAES TRIPLE ZONE VALVE AND BOY COMPLETE ASSEMBLY WITH 1/2x1/2x1/2 O2, 3/4x3/4x3/4 AIR, 1x1x1 VAC VALVES, EACH WITH GAUGE PORTS AND GAUGES, LABELS AND SMOKEED DOOR FINISH ASSEMBLY, BOX ASSEMBLY NUMBER 150307-00, VAC GAUGE NUMBER 130107-00, AIR/O2 GAUGE NUMBER (2) 130108-00.

PROVIDE MEDGAS ALARM PANEL EQUAL TO OHIO MEDICAL CORP. 3-GAS AREA REMOTE ALARM PANEL NUMBER 261853-124. PROVIDE 1/4\" PIPELINE CONNECTION ON TOP OF EACH GAS PIPELINE FOR DISS CHECK VALVE SENSOR AND WIRE TO PANEL CONNECTOR WITH 18GA SHIELDED TWISTED PAIR WIRING. COORDINATE WITH ELECTRICAL CONTRACTOR.

PROVIDE MEDGAS ALARM PANEL EQUAL TO OHIO MEDICAL CORP. 3-GAS AREA REMOTE ALARM PANEL NUMBER 261853-124. PROVIDE 1/4\" PIPELINE CONNECTION ON TOP OF EACH GAS PIPELINE FOR DISS CHECK VALVE SENSOR AND WIRE TO PANEL CONNECTOR WITH 18GA SHIELDED TWISTED PAIR WIRING. COORDINATE WITH ELECTRICAL CONTRACTOR.

PROVIDE NEW ZONE SHUT-OFF VALVE

**KEYED NOTES FOR DWG P3.1**

- ① 3/4\" MEDICAL VACUUM, 1/2\" MEDICAL AIR & 1/2\" MEDICAL OXYGEN PIPING - CONNECT TO HEAD WALL. COORDINATE WITH ARCHITECTURAL DETAILS AND WITH DETAIL 2/PO.3.

**1** 4TH FLOOR MED GAS PLAN - WING A & CORE  
 P3.1 SCALE: 1/8\" = 1'-0\"

FINAL DESIGN (100%)

<b>CONSULTANTS:</b> <b>Hyman Hayes</b> 6 WEMBLEY COURT, ALBANY, NEW YORK 12205 (518) 452-3470 <b>Adelaide</b> Environmental Health Associates, Inc. 1511 Route 22 - Suite C-24 Brewster, New York 10899 p: 845.278.7710 f: 845.278.7750 adelaidelc.com		<b>ENGINEERING VENTURES PC</b> 208 Ryan Avenue, Suite 2A Burlington, VT 05401 tel: 802.863.6225 fax: 802.863.6289 85 Mechanics Street, Suite 350A, Lebanon, NH 03766 tel: 603.442.9330 fax: 603.442.9331				<b>ARCHITECT/ENGINEERS:</b> <b>Sigma Psi Consulting</b> Mechanical, Electrical, Plumbing Engineers, PLLC 4 Collamer Road, Malta, NY 12020 PH (518) 581-9428 FX (518) 580-9325		Drawing Title <b>4TH FLOOR MED GAS PLAN - WING A + CORE</b> Approved Project Director 		Project Title <b>Renovate 4A for Community Living Center (CLC)</b> <b>Stratton VA Medical Center</b> Location <b>Albany, New York</b> Date <b>10-22-2014</b> Checked Drawn		Project Number <b>VA 528A8-12-801</b> Building Number <b>1</b> Drawing Number <b>P3.1</b> Dwg 77 of 117		<b>Office of Construction and Facilities Management</b> 	
---	--	--	--	--	--	--	--	---	--	--	--	---	--	---	--