


three inches = one foot
 one and one half inches = one foot
 one inch = one foot
 three quarters inch = one foot
 one half inch = one foot
 one quarter inch = one foot
 one eighth inch = one foot



- EXISTING CEILING NOTES**
- 1. UNDERSIDE OF EXISTING CONCRETE DECK AT 12'-2" A.F.F.
 - 2. EXISTING 2X4 ACT AT 8'-0" A.F.F.
 - 3. EXISTING 2X4 ACT AT 8'-2" A.F.F.
 - 4. EXISTING 2X4 ACT AT 8'-3" A.F.F.
 - 5. EXISTING 2X4 ACT AT 8'-5"± A.F.F.
 - 6. EXISTING 2X4 ACT AT 8'-6"±±± A.F.F.
 - 7. EXISTING 2X4 ACT AT 8'-7"± A.F.F.
 - 8. EXISTING 2X4 ACT AT 8'-8"± A.F.F.
 - 9. EXISTING 2X4 ACT AT 9'-0"± A.F.F.
 - 10. EXISTING 2X4 ACT AT 10'-0"± A.F.F.
 - 11. EXISTING PLASTER CEILING AT 9'-2"± A.F.F.
 - 12. EXISTING PLASTER CEILING AT 9'-3"± A.F.F.
 - 13. EXISTING PLASTER CEILING AT 9'-5"± A.F.F.
 - 14. EXISTING PLASTER CEILING AT 9'-7"± A.F.F.
 - 15. EXISTING PLASTER CEILING AT 8'-3"± A.F.F.
 - 16. METAL PANEL COOLER CEILING AT 8'-6" A.F.F. (TOP OF COOLER AT 8'-10").
 - 17. EXISTING 2X2 ACT AT 9'-0"± A.F.F.

- KEYED NOTES FOR DWG P2.1**
- 1 4" SOIL - UP
 - 2 3" WASTE - UP
 - 3 2" WET VENT - UP
 - 4 2" VENT - UP
 - 5 2" WASTE - UP
 - 6 1-1/2" WASTE - UP
 - 7 1/2" HW, CW & HWR - UP
 - 8 3/4" HW, CW & HWR - UP
 - 9 CONNECT TO EXISTING STACK.
 - 10 2" VENT - RISE IN CEILING SPACE.

GENERAL NOTES

- ALL SINKS AND LAVATORIES SHALL HAVE HWR PIPING CONNECTED TO THE HW SUPPLY WITHIN 6" OF THE FIXTURE CONNECTION.

1 3RD FLOOR PLUMBING PLAN - WING A
 P2.1 SCALE: 1/8" = 1'-0"

CONSULTANTS: Hyman Hayes <small>1511 Route 22 - Suite C-24 Brewster, New York 10899 p: 845.278.7710 f: 845.278.7750 adelaidelc.com</small>		ENGINEERING VENTURES PC <small>208 Ryan Avenue, Suite 2A Burlington, VT 05401 tel: 802.863.6225 fax: 802.863.6289 85 Mechanics Street, Suite 350A, Lebanon, NH 03756 tel: 603.442.9333 fax: 603.442.9331</small>				ARCHITECT/ENGINEERS: Sigma Psi Consulting Mechanical, Electrical, Plumbing Engineers, PLLC <small>4 Collamer Road, Malta, NY 12020 PH (518) 581-9428 FX (518) 580-9325</small>		Drawing Title 3RD FLOOR PLUMBING PLAN - WING A Approved Project Director 		Project Title Renovate 4A for Community Living Center (CLC) Stratton VA Medical Center Location Albany, New York Date 10-22-2014		Project Number VA 528A8-12-801 Building Number 1 Drawing Number P2.1 Dwg 72 of 117		Office of Construction and Facilities Management 	
---	--	---	--	--	--	---	--	--	--	---	--	---	--	---	--