

Read #	Bldg #	Room	Floor	Comp	Substrate	Side	Cond	Color	Quant	Units	Rec	Lead (mg/cm ²)	Cost/Est.	Priority (1-4)	Dam Pot	Pot Exp	Draw #	Photo ID
1303	10	A106	FIRST	WALL	GWB	A	FAIR	WHITE ON YELLOW	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1304	10	A106	FIRST	SHELVES	WOOD	D	FAIR	YELLOW	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1305	10	E101	FIRST	DOOR	WOOD	C	FAIR	BEIGE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1306	10	A105	FIRST	DOOR	WOOD	A	FAIR	LIGHT PINK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1307	10	A105	FIRST	WALL	PLASTER	C	FAIR	LIGHT PINK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1308	10	A105	FIRST	WINDOW FRAME	METAL	C	FAIR	LIGHT PINK	N/A	N/A	Negative	0.05	N/A	4	LOW	LOW	N/A	N/A
1309	10	A105	FIRST	WINDOW SASH	METAL	C	FAIR	LIGHT PINK	7	EA	Positive	6.61	\$ 1,050.00	2	MOD.	MOD.	SL 10	367
1310	61	EXTERIOR	FIRST	DOOR	METAL	A	FAIR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1311	61	EXTERIOR	FIRST	DOOR FRAME	METAL	A	FAIR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1312	61	EXTERIOR	FIRST	DOOR HEADER	METAL	A	FAIR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1313	61	EXTERIOR	FIRST	VENT PIPE	METAL	A	INTACT	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1314	61	EXTERIOR	FIRST	LOUVER	METAL	D	INTACT	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1315	61	EXTERIOR	FIRST	LOUVER HEADER	METAL	D	POOR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1316	61		100	FIRST FLOOR	CONCRETE	A	POOR	RED	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1317	61		100	FIRST WALL	CMU	A	FAIR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1318	61		100	FIRST ELECTRICAL PANEL	METAL	A	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1319	61		100	FIRST BATTERY CHARGER	METAL	A	FAIR	SILVER	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1320	61		100	FIRST ELECTRICAL BOX	METAL	A	FAIR	DARK GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1321	61		100	FIRST ELECTRICAL BOX	METAL	A	FAIR	DARK GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1322	61		100	FIRST OIL TANK	METAL	A	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1323	61		100	FIRST PIPE VALVE	METAL	A	FAIR	BLUE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1324	61		100	FIRST CIRC PUMP	METAL	A	FAIR	PEWTER	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1325	61		100	FIRST CIRC PUMP BASE	METAL	A	FAIR	PEWTER	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1326	61		100	FIRST CHECK VALVE	METAL	A	INTACT	BLUE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1327	61		100	FIRST EXHAUST DUCT	METAL	C	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1328	61		100	FIRST GENERATOR	METAL	C	FAIR	TAN	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1329	61		100	FIRST GENERATOR BASE	METAL	C	FAIR	TAN	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1330	61		100	FIRST GENERATOR CONTROL PANEL	METAL	B	FAIR	TAN	N/A	N/A	Negative	0.09	N/A	4	LOW	LOW	N/A	N/A
1331	61		100	FIRST GENERATOR CONTROL PANEL	METAL	B	FAIR	GOLD	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1332	61		100	FIRST GENERATOR HEADER MANIFOLD	METAL	A	INTACT	SILVER	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1333	61		100	FIRST DOOR	METAL	A	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1334	61		100	FIRST DOOR FRAME	METAL	A	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1335	61		100	FIRST LOUVER FRAME	METAL	B	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1336	61		100	FIRST LOUVER	METAL	B	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1337	61		100	FIRST HEATER	METAL	C	FAIR	TAN	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1338	61		100	FIRST HEATER	METAL	C	FAIR	TAN	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A

Read #	Bldg #	Room	Floor	Comp	Substrate	Side	Cond	Color	Quant	Units	Ret	Lead (mg/cm ²)	Cont Est.	Priority (1-4)	Dam. Pct	Pot. Exp.	Draw #	Photo ID
1339	61	100	FIRST	HEATER	METAL	C	FAIR	TAN	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1340	61	100	FIRST	HEATER	METAL	C	FAIR	DARK BROWN	N/A	N/A	Negative	0.07	N/A	4	LOW	LOW	N/A	N/A
1341	61	100	FIRST	BATTER STAND	METAL	A	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1342	61	100	FIRST	ROOF JOIST	METAL	B	FAIR	BEIGE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1343	61	100	FIRST	ROOF DECKING	METAL	B	FAIR	BEIGE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1344	7	EXTERIOR	FIRST	DOOR	METAL	A	FAIR	WHITE	3	EA	Positive	3.1	\$ 450.00	2	MOD.	MOD.	SL 7	368
1345	7	EXTERIOR	FIRST	DOOR FRAME	METAL	A	FAIR	WHITE	3	EA	Positive	1.3	\$ 450.00	2	MOD.	MOD.	SL 7	369
1346	7	EXTERIOR	FIRST	DOOR HEADER	METAL	A	FAIR	WHITE	N/A	N/A	Negative	0.4	N/A	4	LOW	LOW	N/A	N/A
1347	7	EXTERIOR	FIRST	DOOR HEADER	METAL	A	FAIR	WHITE	NULL	NULL	NULL	NULL	NULL	NULL	NULL	NULL	NULL	NULL
1348	7	EXTERIOR	FIRST	DOOR HEADER	METAL	A	FAIR	WHITE	1	EA	Positive	1.7	\$ 150.00	2	MOD.	MOD.	SL 7	370
1349	7	EXTERIOR	FIRST	DOOR HEADER	METAL	A	FAIR	RED	NULL	NULL	NULL	NULL	NULL	NULL	NULL	NULL	NULL	NULL
1350	7	EXTERIOR	FIRST	DOOR HEADER	METAL	A	FAIR	RED	1	EA	Positive	10.0	\$ 150.00	2	MOD.	MOD.	SL 7	371
1351	7	EXTERIOR	FIRST	EXHAUST PIPE	METAL	A	POOR	SILVER	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1352	7	EXTERIOR	FIRST	FASTEN SEAT BELT SIGN	METAL	A	FAIR	YELLOW	2	EA	Positive	1.3	\$ 300.00	2	MOD.	MOD.	SL 7	372
1353	7	EXTERIOR	FIRST	LARGE DOOR	METAL	A	FAIR	WHITE	2	EA	Positive	3.5	\$ 300.00	2	MOD.	MOD.	SL 7	373
1354	7	EXTERIOR	FIRST	LARGE DOOR FRAME	METAL	A	FAIR	WHITE	2	EA	Positive	3.0	\$ 300.00	2	MOD.	MOD.	SL 7	374
1355	7	EXTERIOR	FIRST	WINDOW FRAME	METAL	A	INTACT	WHITE	20	EA	Positive	26.7	\$ 3,000.00	2	MOD.	MOD.	SL 7	375
1356	7	EXTERIOR	FIRST	WINDOW SASH	METAL	A	INTACT	WHITE	N/A	N/A	Negative	0.08	N/A	4	LOW	LOW	N/A	N/A
1357	7	EXTERIOR	FIRST	WINDOW SASH AND MUNTIN	METAL	A	INTACT	WHITE	20	EA	Positive	16.0	\$ 3,000.00	2	MOD.	MOD.	SL 7	376
1358	7	EXTERIOR	FIRST	WINDOW HEADER	METAL	A	FAIR	WHITE	20	EA	Positive	14.0	\$ 3,000.00	2	MOD.	MOD.	SL 7	377
1359	7	EXTERIOR	FIRST	AIR COOLED CONDENSER	METAL	D	POOR	SILVER	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1360	7	EXTERIOR	FIRST	VENT PIPE	METAL	D	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1361	7	EXTERIOR	FIRST	ELECTRICAL BOX	METAL	D	INTACT	LIGHT GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1362	7	EXTERIOR	FIRST	RAILING	METAL	D	INTACT	BLACK	N/A	N/A	Negative	0.13	N/A	4	LOW	LOW	N/A	N/A
1363	7	EXTERIOR		BASEM DOOR	WOOD	D	POOR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1364	7	EXTERIOR		BASEM DOOR FRAME	WOOD	D	FAIR	OFF WHITE	1	EA	Positive	28.1	\$ 150.00	2	MOD.	MOD.	SL 7	378
1365	7	EXTERIOR		BASEM RAMP	CONCRETE	D	POOR	DARK GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1366	7	EXTERIOR		BASEM RAMP	CONCRETE	D	POOR	LIGHT GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1367	7	EXTERIOR		BASEM AWNING FRAME	METAL	D	INTACT	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1368	7	EXTERIOR	FIRST	FIRE ALARM BELL	METAL	C	INTACT	RED	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1369	7	EXTERIOR	FIRST	FUEL LINE	METAL	C	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1370	7	EXTERIOR	FIRST	VENT PIPE	METAL	C	FAIR	RED	N/A	N/A	Negative	0.04	N/A	4	LOW	LOW	N/A	N/A
1371	7	EXTERIOR	FIRST	HOSE HOLDER	METAL	C	POOR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1372	7	EXTERIOR	FIRST	PIPE	METAL	C	INTACT	LIGHT YELLOW	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A

Read #	Bldg #	Room	Floor	Comp.	Substrate	Site	Cond.	Color	Quan.	Units	Res.	Lead (mg/cm ²)	Cost Est.	Priority (1-4)	Dam. Pot.	Pot. Exp.	Draw. #	Photo ID.
1373	7	EXTERIOR	FIRST	DRAIN PIPE	METAL	C	POOR	BLACK	N/A	N/A	Negative	0.15	N/A	4	LOW	LOW	N/A	N/A
1374	7	EXTERIOR	FIRST	DOOR SILL	CONCRETE	C	FAIR	RED	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1375	7	EXTERIOR	FIRST	WINDOW GUARD	METAL	C	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1376	7	EXTERIOR	FIRST	SPEAKER	METAL	C	INTACT	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1377	7		FIRST	CEILING	CONCRETE	B	FAIR	BEIGE	N/A	N/A	Negative	0.8	N/A	4	LOW	LOW	N/A	N/A
1378	7		FIRST	ROOF SUPPORT BEAMS	METAL	B	FAIR	BEIGE	1,000	EA	Positive	10.7	\$ 15,000.00	2	MOD.	MOD.	SL 7	379
1379	7		FIRST	CATWALK RAILING	METAL	B	FAIR	BEIGE	N/A	N/A	Negative	0.13	N/A	4	LOW	LOW	N/A	N/A
1380	7		FIRST	CATWALK	METAL	B	FAIR	BEIGE	75	SF	Positive	6.2	\$ 1,125.00	2	MOD.	MOD.	SL 7	380
1381	7		FIRST	OLD TANK FRAME	METAL	B	FAIR	BEIGE	1	EA	Positive	13.0	\$ 1,000.00	2	MOD.	MOD.	SL 7	381
1382	7		FIRST	ROOF HATCH FRAME	METAL	B	POOR	BEIGE	1	EA	Positive	3.9	\$ 175.00	2	HIGH	MOD.	SL 7	382
1383	7		FIRST	CATWALK LADDER	METAL	B	POOR	GRAY ON BLACK	1	EA	Positive	6.1	\$ 250.00	2	HIGH	MOD.	SL 7	383
1384	7		FIRST	STEAM TANK HATCH	METAL	B	FAIR	BLUE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1385	7		FIRST	CEILING SUPPORT BEAMS	METAL	C	POOR	ORANGE	525	SF	Positive	14.7	\$ 8,925.00	2	HIGH	MOD.	SL 7	384
1386	7		FIRST	RAILING	METAL	B	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1387	7		FIRST	LOWER CATWALK	METAL	B	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1388	7		FIRST	LOWER CATWALK	METAL	B	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1389	7		FIRST	STAIR STRINGER&LOWER CATWALK SUPPORTS	METAL	D	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1390	7		FIRST	STAIR TREAD	METAL	B	FAIR	PURPLE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1391	7		FIRST	STEAM TANK FRAME	METAL	A	FAIR	LIGHT GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1392	7		FIRST	WALL	CMU	A	FAIR	OFF WHITE	125	SF	Positive	1.4	\$ 1,875.00	2	HIGH	MOD.	SL 7	385
1393	7		FIRST	WALL	PLASTER	D	FAIR	OFF WHITE	N/A	N/A	Negative	0.16	N/A	4	LOW	LOW	N/A	N/A
1394	7		FIRST	WALL	BRICK	B	INTACT	BEIGE	1,500	SF	Positive	2.2	\$ 15,000.00	2	HIGH	MOD.	SL 7	386
1395	7		FIRST	DOOR	WOOD	A	FAIR	OFF WHITE	1	EA	Positive	3.8	\$ 150.00	2	MOD.	MOD.	SL 7	387
1396	7		FIRST	DOOR FRAME	METAL	A	FAIR	OFF WHITE	1	EA	Positive	6.5	\$ 150.00	2	MOD.	MOD.	SL 7	388
1397	N/A	CALIBRATION	N/A	CALIBRATION	N/A	N/A	N/A	RED	N/A	N/A	Positive	1.0	N/A	N/A	N/A	N/A	N/A	N/A
1398	N/A	CALIBRATION	N/A	CALIBRATION	N/A	N/A	N/A	RED	N/A	N/A	Positive	1.0	N/A	N/A	N/A	N/A	N/A	N/A
1399	N/A	CALIBRATION	N/A	CALIBRATION	N/A	N/A	N/A	RED	N/A	N/A	Positive	1.0	N/A	N/A	N/A	N/A	N/A	N/A
1400	N/A	SELF-CALIBRATION	N/A	SELF-CALIBRATION	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.82	N/A	N/A	N/A	N/A	N/A	N/A
1401	N/A	CALIBRATION	N/A	CALIBRATION	N/A	N/A	N/A	RED	N/A	N/A	Positive	1.0	N/A	N/A	N/A	N/A	N/A	N/A
1402	N/A	CALIBRATION	N/A	CALIBRATION	N/A	N/A	N/A	RED	N/A	N/A	Positive	1.0	N/A	N/A	N/A	N/A	N/A	N/A
1403	N/A	CALIBRATION	N/A	CALIBRATION	N/A	N/A	N/A	RED	N/A	N/A	Positive	1.0	N/A	N/A	N/A	N/A	N/A	N/A

Read #	Blkg #	Room	Floor	Comp.	Substrate	Side	Cond.	Color	Quant.	Units	Res.	Lead (mg/cm ²)	Cost Est.	Priority (1-4)	Dam. Pct.	Pot. Exp.	Draw #	Photo ID
1404	7		102	FIRST MIRROW FRAME	WOOD	B	FAIR	OFF WHITE	N/A	N/A	Negative	0.19	N/A	4	LOW	LOW	N/A	N/A
1405	7		102	FIRST DRAIN PIPE	METAL	B	FAIR	OFF WHITE	25	LF	Positive	12.6	\$ 375.00	2	MOD.	MOD.	SL 7	389
1406	7		102	FIRST WALL	GWB	A	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1407	7		102	FIRST WINDOW INFILL	WOOD	C	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1408	7		102	FIRST DOOR MOLDING	METAL	A	FAIR	OFF WHITE	1	EA	Positive	4.0	\$ 150.00	2	MOD.	MOD.	SL 7	390
1409	7		100	FIRST FLOOR	CONCRETE	B	FAIR	RED	N/A	N/A	Negative	0.3	N/A	4	LOW	LOW	N/A	N/A
1410	7		100	FIRST STAIR TREAD	METAL	A	FAIR	RED	N/A	N/A	Negative	0.09	N/A	4	LOW	LOW	N/A	N/A
1411	7		100	FIRST STAIR STRINGER	METAL	B	FAIR	RED	N/A	N/A	Negative	0.4	N/A	4	LOW	LOW	N/A	N/A
1412	7		100	FIRST COVE BASE	CONCRETE	B	FAIR	RED	550	LF	Positive	2.1	N/A	2	MOD.	MOD.	SL 7	391
1413	7		100	FIRST PIPE	METAL	B	FAIR	YELLOW	15	LF	Positive	5.3	\$ 225.00	2	MOD.	MOD.	SL 7	392
1414	7		105	BASEM RAILING	METAL	A	INTACT	BLACK	225	LF	Positive	2.3	\$ 2,250.00	2	HIGH	MOD.	SL 7	393
1415	7		105	BASEM STAIR NEWEL POST	METAL	A	INTACT	BLACK	N/A	N/A	Negative	0.3	N/A	4	LOW	LOW	N/A	N/A
1416	7		105	BASEM STAIR NEWEL POST	METAL	A	INTACT	BLACK	N/A	N/A	Negative	0.26	N/A	4	LOW	LOW	N/A	N/A
1417	7		105	BASEM STAIR NEWEL POST CAP	METAL	A	INTACT	BLACK	N/A	N/A	Negative	0.7	N/A	4	LOW	LOW	N/A	N/A
1418	7		105	BASEM STAIR STRINGER	METAL	C	FAIR	RED	N/A	N/A	Negative	0.6	N/A	4	LOW	LOW	N/A	N/A
1419	7		105	BASEM STAIR TREAD	METAL	C	INTACT	RED	N/A	N/A	Negative	0.5	N/A	4	LOW	LOW	N/A	N/A
1420	7		105	BASEM CONDUIT	METAL	A	FAIR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1421	7		105	BASEM ELECTRICAL BOX	METAL	A	FAIR	WHITE	N/A	N/A	Negative	0.05	N/A	4	LOW	LOW	N/A	N/A
1422	7		105	BASEM ELECTRICAL BOX	METAL	A	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1423	7		105	BASEM ELECTRICAL PANEL	METAL	A	FAIR	LIGHT GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1424	7		105	BASEM CONDUIT BOX	METAL	B	FAIR	LIGHT GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1425	7		105	BASEM SWITCH GEAR	METAL	B	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1426	7		105	BASEM ELECTRICAL BOX	METAL	B	FAIR	LIGHT BROWN	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1427	7		105	BASEM PIPE	METAL	B	FAIR	LIGHT GRAY	50	LF	Positive	23.9	\$ 750.00	2	MOD.	MOD.	SL 7	394
1428	7		105	BASEM PIPE	METAL	B	FAIR	SILVER	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1429	7		105	BASEM FLOOR	CONCRETE	B	POOR	LIGHT GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1430	7		105	BASEM WALL	CONCRETE	B	FAIR	WHITE	2,000	SF	Positive	1.6	\$ 24,000.00	2	MOD.	MOD.	SL 7	395
1431	7		105	BASEM CIRC PUMP	METAL	C	INTACT	GREEN	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1432	7		105	BASEM CIRC PUMP	METAL	B	INTACT	BLUE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1433	7		105	BASEM CIRC PUMP MOTOR	METAL	C	FAIR	DARK GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1434	7		105	BASEM CIRC PUMP MOTOR	METAL	C	FAIR	DARK GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1435	7		105	BASEM CIRC PUMP MOTOR	METAL	B	INTACT	SILVER	N/A	N/A	Negative	0.1	N/A	4	LOW	LOW	N/A	N/A
1436	7		105	BASEM CIRC PUMP FOUNDATION	CONCRETE	A	FAIR	YELLOW	3	EA	Positive	2.2	\$ 225.00	2	MOD.	MOD.	SL 7	396
1437	7		105	BASEM PIPE	TSI	B	FAIR	GREEN	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1438	7		105	BASEM PIPE	METAL	D	FAIR	GREEN	N/A	N/A	Negative	0.8	N/A	4	LOW	LOW	N/A	N/A
1439	7		105	BASEM SUMP PUMP	METAL	D	INTACT	SILVER	N/A	N/A	Negative	0.3	N/A	4	LOW	LOW	N/A	N/A
1440	7		105	BASEM SUMP PUMP CAP	METAL	D	INTACT	YELLOW	N/A	N/A	Negative	0.7	N/A	4	LOW	LOW	N/A	N/A

Read #	Bldg #	Room	Floor	Comp.	Substrate	Side	Cond.	Color	Quan.	Units	Res.	Lead (mg/cm ²)	Cost Est.	Priority (1-4)	Dam. Pot.	Pol. Exp.	Draw. #	Photo ID.
1441	7		105	SUMP PUMP FOUNDATION	CONCRETE	D	FAIR	YELLOW	3	EA	Positive	2.1	\$ 225.00	2	MOD.	MOD.	SL 7	397
1442	7		105	BASEN STEAM LINE	TSI	C	FAIR	YELLOW	2,000	LF	Positive	5.8	\$ 24,000.00	2	MOD.	MOD.	SL 7	398
1443	7		105	BASEN TANK	TSI	B	FAIR	YELLOW	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1444	7		105	BASEN COLUMN	METAL	C	FAIR	BURGUNDY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1445	7		105	BASEN COLUMN BASE	CONCRETE	C	FAIR	LIGHT GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1446	7		105	BASEN TANK STAND	METAL	D	FAIR	LIGHT GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1447	7		105	BASEN STEAM TRAP	METAL	D	FAIR	METALLIC BLUE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1448	7		105	BASEN HEATING PUMP COVER	METAL	B	FAIR	YELLOW	3	EA	Positive	5.0	\$ 225.00	2	MOD.	MOD.	SL 7	399
1449	7		105	BASEN HEATING PUMP PIPE	METAL	B	FAIR	SILVER	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1450	7		105	BASEN HEATING PUMP ELECTRICAL BOARD	METAL	B	FAIR	BLACK	N/A	N/A	Negative	0.2	N/A	4	LOW	LOW	N/A	N/A
1451	7		105	BASEN CIRC PUMP	METAL	A	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1452	7		105	BASEN HEATING PUMP FOUNDATION	CONCRETE	D	POOR	GRAY ON RED ON GREEN	2	EA	Positive	4.2	\$ 200.00	2	MOD.	MOD.	SL 7	400
1453	7		105	BASEN FLOOR	CONCRETE	C	POOR	GRAY ON RED ON GREEN	N/A	N/A	Negative	0.09	N/A	4	LOW	LOW	N/A	N/A
1454	7		105	BASEN PIPE LADDER	METAL	D	INTACT	YELLOW	1	EA	Positive	5.2	\$ 75.00	2	HIGH	MOD.	SL 7	401
1455	7		105	BASEN WALL	CMU	D	FAIR	WHITE	175	SF	Positive	10.0	\$ 2,100.00	2	MOD.	MOD.	SL 7	402
1456	7		105	BASEN HOSE HOLDER	METAL	D	FAIR	WHITE	N/A	N/A	Negative	0.16	N/A	4	LOW	LOW	N/A	N/A
1457	7	104A		BASEN FLOOR	CONCRETE	C	INTACT	RED	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1458	7	104A		BASEN DOOR FRAME	METAL	B	FAIR	DARK OLIVE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1459	7	104A		BASEN WALL	CONCRETE	D	FAIR	OFF WHITE	N/A	N/A	Negative	0.04	N/A	4	LOW	LOW	N/A	N/A
1460	7	104A		BASEN WALL	CONCRETE	D	FAIR	WHITE	N/A	N/A	Negative	0.04	N/A	4	LOW	LOW	N/A	N/A
1461	7	104A		BASEN CONDUIT	METAL	D	FAIR	OFF WHITE	N/A	N/A	Negative	0.04	N/A	4	LOW	LOW	N/A	N/A
1462	7	104A		BASEN CEILING	CONCRETE	C	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1463	7	104A		BASEN CEILING	CONCRETE	C	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1464	7	104A		BASEN TOOL RACK	WOOD	D	FAIR	RED	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1465	7	104A		BASEN WALL	CMU	C	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1466	7		104	BASEN FLOOR	CONCRETE	C	POOR	BEIGE	150	SF	Positive	1.7	\$ 1,800.00	2	MOD.	MOD.	SL 7	403
1467	7		104	BASEN CEILING	CONCRETE	A	POOR	BEIGE	N/A	N/A	Negative	0.12	N/A	4	LOW	LOW	N/A	N/A
1468	7		104	BASEN WALL	BRICK	B	INTACT	BEIGE	N/A	N/A	Negative	0.15	N/A	4	LOW	LOW	N/A	N/A
1469	7		104	BASEN GENERATOR FOUNDATION	CONCRETE	B	INTACT	BEIGE	N/A	N/A	Negative	0.26	N/A	4	LOW	LOW	N/A	N/A
1470	7		104	BASEN GENERATOR	METAL	B	FAIR	BEIGE	N/A	N/A	Negative	0.07	N/A	4	LOW	LOW	N/A	N/A

Read #	Bldg #	Room	Floor	Comp.	Substrate	Side	Cond.	Color	Quant.	Units	Res.	Lead (mg/cm ²)	Cost Est.	Priority (1-4)	Dam. Pot.	Pot. Exp.	Draw #	Photo ID
1471	7		104	GENERATOR HEADER MANAFOLD	METAL	B	INTACT	SILVER	N/A	N/A	Negative	0.04	N/A	4	LOW	LOW	N/A	N/A
1472	7		104	BASEM GENERATOR	METAL	B	FAIR	GREEN	1	EA	Positive	1.2	\$ 500.00	2	MOD.	MOD.	SL 7	404
1473	7		104	BASEM GENERATOR PIPE	METAL	B	FAIR	GREEN	N/A	N/A	Negative	0.4	N/A	4	LOW	LOW	N/A	N/A
1474	7		104	BASEM GENERATOR BATTERY TRAY	METAL	B	INTACT	BEIGE	N/A	N/A	Negative	0.04	N/A	4	LOW	LOW	N/A	N/A
1475	7		104	BASEM GENERATOR BATTERY TRAY	METAL	B	INTACT	BEIGE	N/A	N/A	Negative	0.06	N/A	4	LOW	LOW	N/A	N/A
1476	7		104	BASEM GENERATOR BATTERY TRAY	METAL	B	INTACT	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1477	7		104	BASEM GENERATOR CONTROL PANEL	METAL	C	FAIR	BEIGE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1478	7		104	BASEM GENERATOR CONTROL PANEL	METAL	C	FAIR	BEIGE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1479	7		104	BASEM CONDUIT BOX	METAL	C	FAIR	BEIGE	N/A	N/A	Negative	0.11	N/A	4	LOW	LOW	N/A	N/A
1480	7		104	BASEM DOOR TRIM	WOOD	C	FAIR	BEIGE	N/A	N/A	Negative	0.21	N/A	4	LOW	LOW	N/A	N/A
1481	7		104	BASEM DOOR FRAME	WOOD	C	FAIR	BEIGE	N/A	N/A	Negative	0.19	N/A	4	LOW	LOW	N/A	N/A
1482	7	103A		BASEM WALL	GWB	D	FAIR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1483	7	102B		BASEM CEILING HATCH	METAL	D	FAIR	BEIGE	4	EA	Positive	3.9	\$ 300.00	2	MOD.	MOD.	SL 7	405
1484	7	102B		BASEM CEILING	CONCRETE	D	FAIR	BEIGE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1485	7	102B		BASEM WALL	CONCRETE	A	FAIR	BEIGE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1486	7	102B		BASEM FLOOR	CONCRETE	A	POOR	LIGHT GRAY	N/A	N/A	Negative	0.04	N/A	4	LOW	LOW	N/A	N/A
1487	7	102B		BASEM COLUMN	CONCRETE	C	FAIR	BEIGE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1488	7	102B		BASEM DOOR	METAL	C	FAIR	TEAL	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1489	7	102B		BASEM DOOR FRAME	METAL	C	FAIR	TEAL	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1490	7	103A		BASEM DOOR RACK	WOOD	A	FAIR	TEAL	N/A	N/A	Negative	0.1	N/A	4	LOW	LOW	N/A	N/A
1491	7	103A		BASEM TOOL RACK	WOOD	C	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1492	7	103A		BASEM DOOR TRIM	WOOD	B	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1493	7	103A		BASEM DOOR	WOOD	B	FAIR	OFF WHITE	1	EA	Positive	5.6	\$ 500.00	2	MOD.	MOD.	SL 7	406
1494	7	103A		BASEM DOOR FRAME	WOOD	B	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1495	7		103	BASEM WALL	CONCRETE	B	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1496	7		103	BASEM WALL	CONCRETE	C	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1497	7		103	BASEM WALL	CONCRETE	A	FAIR	OFF WHITE	2,000	SF	Positive	2.6	\$ 24,000.00	2	MOD.	MOD.	SL 7	407
1498	7		103	BASEM COVE BASE	CONCRETE	A	INTACT	GREEN	1,000	LF	Positive	2.0	\$ 5,000.00	2	MOD.	MOD.	SL 7	408
1499	7		103	BASEM WALL	GWB	C	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1500	7		103	BASEM WALL	GWB	C	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1501	7		103	BASEM DOOR FRAME	METAL	C	FAIR	BLUE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1502	7		103	BASEM WINDOW SILL	GWB	C	FAIR	BLUE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A

Read #	Bldg #	Room	Floor	Comp.	Substrate	Side	Cond.	Color	Quan.	Units	Res.	Lead (mg/cm ²)	Cost Est.	Priority (1-5)	Dam. Pot.	Pot. Exp.	Draw #	Photo ID
1503	7		103	BASEN BOILER CONTROL FOUNDATION	CONCRETE	A	FAIR	BLUE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1504	7		103	BASEN BOILER CONTROL PANEL	METAL	D	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1505	7		103	BASEN BOILER CONTROL PANEL	METAL	D	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1506	7		103	BASEN DOOR TRIM	WOOD	A	FAIR	OFF WHITE	N/A	N/A	Negative	0.13	N/A	4	LOW	LOW	N/A	N/A
1507	7		103	BASEN DOOR FRAME	WOOD	A	FAIR	OFF WHITE	N/A	N/A	Negative	0.1	N/A	4	LOW	LOW	N/A	N/A
1508	7		103	BASEN DUCT	METAL	A	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1509	7		103	BASEN FIRE NOTIFIER	METAL	A	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1510	7		103	BASEN FIRE NOTIFIER	METAL	A	FAIR	RED	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1511	7		103	BASEN ELECTRICAL PANEL	METAL	A	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1512	7		103	BASEN CONDUIT	METAL	B	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1513	7		103	BASEN BELL	METAL	B	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1514	7		103	BASEN CHAULK BOARD FRAME	WOOD	B	FAIR	OFF WHITE	N/A	N/A	Negative	0.03	N/A	4	LOW	LOW	N/A	N/A
1515	7		103	BASEN CABINET	WOOD	B	FAIR	LIGHT GREEN	N/A	N/A	Negative	0.07	N/A	4	LOW	LOW	N/A	N/A
1516	7		100	BASEN PRESSURE GAUGE PANEL	WOOD	B	FAIR	GREEN	N/A	N/A	Negative	0.05	N/A	4	LOW	LOW	N/A	N/A
1517	7		100	BASEN PIPE HANGER	METAL	B	FAIR	OFF WHITE	N/A	N/A	Negative	0.14	N/A	4	LOW	LOW	N/A	N/A
1518	7		100	BASEN DOOR FRAME	METAL	B	FAIR	OFF WHITE	1	EA	Positive	8.5	\$ 500.00	2	MOD.	MOD.	SL 7	409
1519	7		100	BASEN COVE BASE	CONCRETE	B	FAIR	OFF WHITE	NULL	NULL	NULL	NULL	NULL	NULL	NULL	NULL	NULL	NULL
1520	7		100	BASEN COVE BASE	CONCRETE	B	FAIR	OFF WHITE	1,000	LF	Positive	2.1	\$ 5,000.00	2	MOD.	MOD.	SL 7	410
1521	7		100	BASEN FEED WATER PUMP	METAL	B	FAIR	OFF WHITE	N/A	N/A	Negative	0.16	N/A	4	LOW	LOW	N/A	N/A
1522	7		100	BASEN FLOOR	CONCRETE	C	POOR	OFF WHITE	N/A	N/A	Negative	0.26	N/A	4	LOW	LOW	N/A	N/A
1523	7		100	BASEN FLOOR TROUGH COVER	METAL	C	POOR	OFF WHITE	N/A	N/A	Negative	0.11	N/A	4	LOW	LOW	N/A	N/A
1524	7		100	BASEN NATURAL GAS LINE	METAL	C	FAIR	ORANGE	225	LF	Positive	5.3	\$ 1,125.00	2	MOD.	MOD.	SL 7	411
1525	7		100	BASEN FUEL OIL LINE	METAL	C	FAIR	YELLOW	225	LF	Positive	17.5	\$ 1,125.00	2	MOD.	MOD.	SL 7	412
1526	7		100	BASEN FUEL OIL STRAINER	METAL	C	FAIR	GRAY	N/A	N/A	Negative	0.13	N/A	4	LOW	LOW	N/A	N/A
1527	7		100	BASEN FUEL OIL PUMP	METAL	C	FAIR	GRAY	N/A	N/A	Negative	0.23	N/A	4	LOW	LOW	N/A	N/A
1528	7		100	BASEN FUEL OIL PUMP MOTOR	METAL	C	FAIR	GRAY	N/A	N/A	Negative	0.28	N/A	4	LOW	LOW	N/A	N/A
1529	7		100	BASEN FUEL OIL PUMP MOTOR STAND	METAL	C	INTACT	GRAY	N/A	N/A	Negative	0.14	N/A	4	LOW	LOW	N/A	N/A
1530	7		100	BASEN FUEL OIL PUMP MOTOR SWITCH	METAL	C	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1531	7		100	BASEN BOILER BASE	METAL	C	FAIR	GREEN	N/A	N/A	Negative	0.4	N/A	4	LOW	LOW	N/A	N/A
1532	7		100	BASEN BOILER BASE	METAL	C	FAIR	GREEN	N/A	N/A	Negative	0.5	N/A	4	LOW	LOW	N/A	N/A
1533	7		100	BASEN BOILER LADDER	METAL	C	FAIR	GREEN	N/A	N/A	Negative	0.26	N/A	4	LOW	LOW	N/A	N/A

Read #	Bldg #	Room	Floor	Comp.	Substrate	Side	Cont.	Color	Quan.	Units	Res.	Lead (mg/cm ³)	Cost Est.	Priority (1-4)	Dam. Pot.	Ret. Exp.	Draw #	Photo ID
1534	7	100 BASEM	100 BASEM	BOILER CATWALK RAILING	METAL	C	FAIR	GREEN	N/A	N/A	Negative	0.5	N/A	4	LOW	LOW	N/A	N/A
1535	7	100 BASEM	100 BASEM	BOILER CATWALK	METAL	C	FAIR	GREEN	N/A	N/A	Negative	0.3	N/A	4	LOW	LOW	N/A	N/A
1536	7	100 BASEM	100 BASEM	BOILER	METAL	C	FAIR	RED	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1537	7	100 BASEM	100 BASEM	BOILER	METAL	C	FAIR	RED	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1538	7	100 BASEM	100 BASEM	BOILER	METAL	C	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1539	7	100 BASEM	100 BASEM	BOILER	METAL	C	FAIR	BLACK	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1540	7	100 BASEM	100 BASEM	BOILER	METAL	C	FAIR	GREEN	N/A	N/A	Negative	0.4	N/A	4	LOW	LOW	N/A	N/A
1541	7	100 BASEM	100 BASEM	BOILER TANK	METAL	B	FAIR	GREEN	N/A	N/A	Negative	0.5	N/A	4	LOW	LOW	N/A	N/A
1542	7	100 BASEM	100 BASEM	BOILER TANK HOLDER	METAL	B	FAIR	GREEN	N/A	N/A	Negative	0.5	N/A	4	LOW	LOW	N/A	N/A
1543	7	100 BASEM	100 BASEM	VALVE HANDLE	METAL	C	INTACT	RED	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1544	7	100 BASEM	100 BASEM	BOILER PIPE	METAL	A	INTACT	SILVER	N/A	N/A	Negative	0.08	N/A	4	LOW	LOW	N/A	N/A
1545	7	100 BASEM	100 BASEM	BOILER CONTROL PANEL	METAL	B	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1546	7	100 BASEM	100 BASEM	DOOR TRIM	WOOD	D	INTACT	OFF WHITE	1	EA	Positive	8.0	\$ 150.00	2	MOD.	MOD.	SL 7	413
1547	7	100 BASEM	100 BASEM	DOOR	WOOD	D	INTACT	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1548	7	100 BASEM	100 BASEM	FLOOR	CONCRETE	A	POOR	GRAY	N/A	N/A	Negative	0.27	N/A	4	LOW	LOW	N/A	N/A
1549	7	100 BASEM	100 BASEM	TRANSFORMER	METAL	D	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1550	7	100 BASEM	100 BASEM	ALARM PANEL	METAL	A	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1551	7	102 BASEM	102 BASEM	FLOOR	CONCRETE	C	POOR	GRAY ON RED	N/A	N/A	Negative	0.03	N/A	4	LOW	LOW	N/A	N/A
1552	7	102 BASEM	102 BASEM	COVE BASE	CONCRETE	C	FAIR	GRAY	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1553	7	102 BASEM	102 BASEM	AC UNIT	METAL	B	FAIR	OLIVE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1554	7	102 BASEM	102 BASEM	DOOR FRAME	METAL	A	FAIR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1555	7	102 BASEM	102 BASEM	DOOR	METAL	A	FAIR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1556	7	100 FIRST	100 FIRST	WINDOW SILL	CONCRETE	C	FAIR	OFF WHITE	N/A	N/A	Negative	0.13	N/A	4	LOW	LOW	N/A	N/A
1557	7	100 FIRST	100 FIRST	WINDOW SASH-MUNTIN	METAL	C	FAIR	OFF WHITE	20	EA	Positive	6.0	\$ 3,000.00	2	MOD.	MOD.	SL 7	414
1558	7	101 FIRST	101 FIRST	DOOR	METAL	C	FAIR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1559	7	101 FIRST	101 FIRST	DOOR FRAME	METAL	C	FAIR	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1560	7	100 FIRST	100 FIRST	DOOR	METAL	A	FAIR	WHITE	N/A	N/A	Negative	0.15	N/A	4	LOW	LOW	N/A	N/A
1561	7	100 FIRST	100 FIRST	DOOR FRAME	METAL	A	FAIR	OFF WHITE	N/A	N/A	Negative	0.11	N/A	4	LOW	LOW	N/A	N/A
1562	7	100 FIRST	100 FIRST	DOOR	METAL	A	FAIR	WHITE	N/A	N/A	Negative	0.11	N/A	4	LOW	LOW	N/A	N/A
1563	7	100 FIRST	100 FIRST	DOOR TRIM	WOOD	A	FAIR	OFF WHITE	N/A	N/A	Negative	0.09	N/A	4	LOW	LOW	N/A	N/A
1564	7	100 FIRST	100 FIRST	DOOR THRESHOLD	METAL	A	POOR	OFF WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1565	13 EXTERIOR	FIRST	FIRST	LOADING DOCK WALL	CONCRETE	A	INTACT	WHITE	N/A	N/A	Negative	< LOD	N/A	4	LOW	LOW	N/A	N/A
1566	13 EXTERIOR	FIRST	FIRST	LOADING DOCK CORNER	METAL	A	POOR	LIGHT YELLOW	100	SF	Positive	5.4	\$ 1,500.00	2	HIGH	HIGH	SL 13	415