

VA251-15-B-0266

Renovate SAR and Rec Room Building 104

Request for Information

As of 6/5/2013

Q1. There is a spec section 14 41 10 "Patient Lifts" but we can not find them on the drawings. Please advise.

A1. No Patient lifts will be installed by the successful contractor. They will be installed at a later time by a lift provider