

**REQUEST FOR INFORMATION (RFI)****VA251-15-B-0305**

PROJECT NUMBER:	515-15-101	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.
PROJECT TITLE:	Construction Additional Fire Bay B25	
PROJECT LOCATION:	Department of Veterans Affairs Battle Creek VA Medical Center 5500 Armstrong Road Battle Creek, MI 49037	

SUBMITTED BY:	Harry Armitage / J&L Electric	City/State:	Battle Creek, MI
PHONE NO.:	269-962-0774 X116		

**TO:** Contracting Specialist Sonny S. Earls  
Sonny.Earls@va.gov

RFI NO.:	DATE: 6/10/2015	REFERENCE:
REPLY NEEDED BY:		

**INFORMATION NEEDED:**

Are there any more detailed specs for the cable receptacle reels? There is a wide variety in price and duty rating.

**REPLY:**

Provide heavy duty single receptacle power cord reel with the following specifications. Verify with COR compatibility with mating receptacle on vehicle.

No. of Conductors: 3  
Cord Type: SJEOW  
Current: 20 A  
Certification: UL Listed  
Frequency: 60 Hz  
Cord Length: 45 ft  
Voltage: 125 V  
Cord Thickness: 12 AWG  
Cord Included  
Spring Drive Retractable with Latch  
Adjustable Cord Stop  
Durable Abrasion and Corrosion Resistant Baked-on Powder Coat Finish  
Wall, Ceiling, and Bench Mount

**APPROVED***By Christopher Hover at 7:19 am, Jun 15, 2015*

REPLY FROM: Jim Hyde, P.E.	DATE: 12 June 2015
ATTACHMENTS:	COPY TO: